

TEST REPORT IEC 61727 Photovoltaic (PV) systems – Characteristics of the utility interface

Report Number.....: GZES191002576301

Date of issue.....: 07/11/2019

Total number of pages 19

Name of Testing Laboratory

preparing the Report SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou

Branch

Applicant's name: EVOLVE ENERGY GROUP CO., LIMITED

Address.....: RM 702, 7/F FU FAI COMM CTR 27 HILLIER ST SHEUNG

WAN, HK

Test specification:

Standard: IEC 61727:2004 (Second Edition)

Test procedure: Characteristic Examination

Non-standard test method: N/A

Test Report Form No.: IEC61727A

Test Report Form(s) Originator: TÜV SÜD Product Service GmbH

Master TRF: Dated 2014-11

Copyright © 2014 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description:	Solar Grid-tied Inverter
Trade Mark:	EVVO
Manufacturer:	EVOLVE ENERGY GROUP CO., LIMITED
Address:	RM 702, 7/F FU FAI COMM CTR 27 HILLIER ST SHEUNG WAN, HK
Model/Type reference:	EVVO 3200TL-AV, EVVO 3000TL-AV, EVVO 2700TL-AV,
	EVVO 2200TL-AV, EVVO 1600TL-AV, EVVO 1100TL-AV
Ratings:	See model list in Page 2.
	Serial Number: SA3ES033K4P001, SA3ES027K4P020
	Firmware version: V100



Responsible Testing Laboratory (as appli	cable), testing procedure	and testing location(s):
☐ CB Testing Laboratory:		
Testing location/ address		
Associated CB Testing Laboratory:		
Testing location/ address		
Tested by (name, function, signature)	÷	
Approved by (name, function, signature).	÷	
☐ Testing procedure: TMP/CTF Stage	1: Shenzhen SOFAR SO	LAR Co., Ltd.
Testing location/ address	XingDong Community,	gDa Industrial Park, District 68, XinAn Street, BaoAn District, dong Province, P.R. China
Tested by (name, function, signature)	Hugo Zhang Project Engineer)	Hugo Zhang
Approved by (name, function signature	型 多	Rogerber
☐ Testing procedure: WMT/CTF Stage	2.	
Testing location/ address	+	
Tested by (name, function, signature)		
Witnessed by (name, function, signature)		
Approved by (name, function, signature).	.:	
Testing procedure: SMT/CTF Stage 3 or 4:		
Testing location/ address		
Tested by (name, function, signature)		
Witnessed by (name, function, signature)		
Approved by (name, function, signature).	.i	
Supervised by (name, function, signature)÷	



List of Attachments (including a total number of pages in each attachment):

	50 Hz	
Attachment #	Description	Pages
Attachment I	Pictures of the EUT and Electrical Schemes	12 pages
Attachment II	Testing Information	4 pages
Attachment III	Graphs and Screenshots of Test Results	21 pages

Summary of testing:

Tests performed (name of test and test clause):

The equipment has been tested according to the standard:

IEC 61727:2004. Testing has been carried out at 50 Hz

All applicable tests according to the above specified standard have been carried out.

From the result of inspection and tests on the submitted sample, we conclude that it complies with the requirements of the standard.

Remarks: All the test results are from the report below:

- IEC 61727:2004 (Second Edition)
Test Report No: 2219 / 0185-A-E1 which was issued by SGS Tecnos, S.A. (Electrical Testing Laboratory) on 26/07/2019

Testing location:

Shenzhen SOFAR SOLAR Co., Ltd.

401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen City, Guangdong Province, P.R. China


(All clauses)

Summary of compliance with National Differences:

No National Differences are addressed to this test report




Copy of marking plate(representative):



Note:

- The above markings are the minimum requirements required by the safety standard. For the final
 production samples, the additional markings which do not give rise to misunderstanding may be
 added.
- 2. Label is attached on the side surface of enclosure and visible after installation
- 3. Labels of other models are as the same with EVVO 3200TL-AV's except the parameters of rating.





Test item particulars:	Solar Grid-tied Inverter (Single Phase Inverter)
Classification of installation and use:	Fixed (permanent connection)
Supply Connection:	DC; PV
:	AC; Grid connection
Possible test case verdicts:	
- test case does not apply to the test object:	N/A
- test object does meet the requirement:	P (Pass)
- test object does not meet the requirement:	F (Fail)
Testing:	CTF Stage 1 procedure
Date of receipt of test item:	N/A
Date (s) of performance of tests:	From 16/04/2019 to 11/06/2019
General remarks:	
"(See Enclosure #)" refers to additional information ap "(See appended table)" refers to a table appended to the	
This document is issued by the Company subject to its General Co accessible at www.sgs.com/terms and conditions.htm and, for ele Electronic Documents at www.sgs.com/terms e-document.htm. At jurisdiction issues defined therein. Any holder of this document is a findings at the time of its intervention only and within the limits of C its Client and this document does not exonerate parties to a transa transaction documents. This document cannot be reproduced exce unauthorized alteration, forgery or falsification of the content or approsecuted to the fullest extent of the law. Unless otherwise stated tested. Throughout this report a comma / point is uniteral comma / comma / point is uniteral comma / comma / point is uniteral comma / comma /	ctronic format documents, subject to Terms and Conditions for tention is drawn to the limitation of liability, indemnification and dvised that information contained hereon reflects the Company's lient's instructions, if any. The Company's sole responsibility is to ction from exercising all their rights and obligations under the pt in full, without prior written approval of the Company. Any pearance of this document is unlawful and offenders may be the results shown in this test report refer only to the sample(s)
Manufacturer's Declaration per sub-clause 4.2.5 of	IECEE 02:
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided	☐ Yes ☐ Not applicable
When differences exist; they shall be identified in t	he General product information section.
Name and address of factory (ies):	Dongguan SOFAR SOLAR Co.,Ltd. 1F - 6F, Building E, No. 1 JinQi Road, Bihu Industrial Park, Wulian Village, Fenggang Town, Dongguan City,Guangdong Province,P.R. China.



General product information:

Product covered by this report is grid-connected PV inverter for indoor or outdoor installation. The connection to the DC input and AC output are through connectors.

The Solar inverter converts DC voltage into AC voltage.

The input and output are protected by varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit can operate in case of one error.

Equipment Under Testing:

EVVO 3200TL-AV

Variant models:

- EVVO 3000TL-AV
- EVVO 2700TL-AV
- EVVO 2200TL-AV
- EVVO 1600TL-AV
- EVVO 1100TL-AV

Model Number	EVVO 3200TL-AV	EVVO 3000TL-AV	EVVO 2700TL-AV	EVVO 2200TL-AV	EVVO 1600TL-AV	EVVO 1100TL-AV	
Max. input voltage		550Vd.c.			500Vd.c		
Max. input current	12Ad.c.	12Ad.c.	12Ad.c.	12Ad.c.	12Ad.c.	12Ad.c.	
Operating MPPT voltage range		50-550Vd.c.			50-500Vd.c.		
Full load DC Voltage Range	300-500 Vd.c.	275-500 Vd.c.	250-500 Vd.c.	200-450 Vd.c.	150-450 Vd.c.	110-450 Vd.c.	
Rated voltage	360V						
Rated grid voltage	230Va.c.						
Rated grid frequency	50Hz						
Rated output power	3.3kW	3.0kW	2.7kW	2.2kW	1.6kW	1.1kW	
Rated output current	13Aa.c.	13 Aa.c.	11.8Aa.c.	9.6Aa.c.	7Aa.c.	4.8Aa.c.	
Max. Output Current	16Aa.c.	14.5 Aa.c.	13Aa.c.	10.6Aa.c.	7.7Aa.c.	5.3Aa.c.	
Power factor		0.8 leading to 0.8 lagging					
Ambient temperature	-30 °C ~60°C						
Ingress protection	IP65						
Protective class			Cla	ss I			

The variants models have been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology
- Same control algorithm.
- Output power within 2.5 and 2/3 of the EUT or Modular inverters.
- Same Firmware Version

Page 8 of 19



	IEC 61727		
Clause	Requirement + Test	Result - Remark	Verdict
4	UTILITY COMPATIBILITY		Р
	The quality of power provided by the PV system for the on-site AC loads and for power delivered to the utility is governed by practices and standards on voltage, flicker, frequency, harmonics and power factor.		P
	Deviation from these standards represents out-of- bounds conditions and may require the PV system to sense the deviation and properly disconnect from the utility system.		Р
4.1	Voltage, current and frequency		P
	The PV system AC voltage, current and frequency are compatible with the utility system.		Р
4.2	Normal voltage operating range		Р
	Utility-interconnected PV systems do not normally regulate voltage, they inject current into the utility. Therefore, the voltage operating range for PV inverters is selected as a protection function that responds to abnormal utility conditions, not as a voltage regulation function.		P
4.3	Flicker		Р
	The operation of the PV system is not cause voltage flicker in excess of limits stated in the relevant sections of IEC 61000-3-3 for systems less than 16 A or IEC 61000-3-5 for systems with current of 16 A and above.	(see appended table)	Р
4.4	DC injection	,	Р
	The PV system is not inject DC current greater than 1 % of the rated inverter output current, into the utility AC interface under any operating condition.	(see appended table)	Р
4.5	Normal frequency operating range		Р
	The PV system operates in synchronism with the utility system, and within the frequency trip limits defined in 5.2.2.		Р
4.6	Harmonics and waveform distortion		Р
	Total harmonic current distortion is less than 5 % at rated inverter output. Each individual harmonic is limited to the percentages listed in Table 1.	(see appended table)	Р
	Even harmonics in these ranges is less than 25 % of the lower odd harmonic limits listed.		Р



		IEC 61727				
Clause	Requirement + Test		Result - Remark	Verdict		
	Table 1 – Current distortion limits					
	Odd harmonics	Distortion limit				
	3 rd through 9 th	Less than 4,0 %				
	11 th through 15 th	Less than 2,0 %				
	17 th through 21 st	Less than 1,5 %				
	23 rd through 33 rd	Less than 0,6 %				
	Even harmonics	Distortion limit				
	2 rd through 8 th	Less than 1,0 %				
	10 th through 32 nd	Less than 0,5 %				
4.7	The PV system has a lagging than 0,9 when the output is g rated inverter output power.	power factor greater	(see appended table)	P		
5	PERSONNEL SAFETY AND	EQUIPMENT PROTEC	CTION	Р		
	This Clause provides information and considerations for the safe and proper operation of the utility-connected PV systems.					
5.1	Loss of utility voltage		P			
	To prevent islanding, a utility connected PV system ceases to energize the utility system from a deenergized distribution line irrespective of connected loads or other generators within specified time limits.					
	A utility distribution line can b for several reasons. For exam- breaker opening due to fault of distribution line switched out		P			
5.2	Over/under voltage and fre			Р		
	The abnormal utility condition voltage and frequency excurs the values stated in this Claudisconnection of the utility, proof or a distributed resource isla	sions above or below se, and the complete esenting the potential	(see appended table)	Р		
5.2.1	Over/under voltage		I.	Р		
	When the interface voltage deviates outside the conditions specified in Table 2, the photovoltaic system ceases to energize the utility distribution system. This applies to any phase of a multiphase system. (see appended table)					
	Table 2 – Response to al	onormal voltages		Р		
	Voltage (at point of utility connection)	Maximum trip time*				
	V < 0,5 × Vnominal	0,1 s				
	50 % ≤ V < 85 %	2,0 s				
	85 % ≤ V ≤ 110 %	Continuous operation				
	110 % < V < 135 %	2,0 s				
	* Trip time refers to the time between the abnor ceasing to energize the utility line. The Pv remain connected to the utility to allow sensi	system control circuits shall actually				
	by the "reconnect" feature.			_		
5.2.2	Over/under frequency			P		







	IEC 61727		
Clause	Requirement + Test	Result - Remark	Verdict
	When the utility frequency deviates outside the specified conditions the photovoltaic system ceases to energize the utility line. The unit does not have to cease to energize if the frequency returns to the normal utility continuous operation condition within the specified trip time.	(see appended table)	Р
	When the utility frequency is outside the range of ±1 Hz, the system ceases to energize the utility line within 0,2 s. The purpose of the allowed range and time delay is to allow continued operation for short-term disturbances and to avoid excessive nuisance tripping in weak-utility system conditions.		Р
5.3	Islanding protection		Р
	The PV system must cease to energize the utility line within 2 s of loss of utility.	Test according IEC 62116: 2014 Refer to Test report No: GZES191002576302	Р
5.4	Response to utility recovery		Р
	Following an out-of-range utility condition that has caused the photovoltaic system to cease energizing, the photovoltaic system is not energize the utility line for 20 s to 5 min after the utility service voltage and frequency have recovered to within the specified ranges.	(see appended table)	Р
5.5	Earthing		Р
	The utility interface equipment is earthed/grounded in accordance with IEC 60364-7-712.		Р
5.6	Short circuit protection		P
	The photovoltaic system has short-circuit protection in accordance with IEC 60364-7-712.		Р
5.7	Isolation and switching		Р
	A method of isolation and switching is provided in accordance with IEC 60364-7-712.		Р



Page 11 of 19

Report No. GZES191002576301

IEC 61727				
Clause	Requirement + Test	Result - Remark	Verdict	

4.3	TABLE	:: Flicker			P
		Starting Stopping Running		ning	
Limit		4%	4%	Pst = 1.0	PIt = 0.65
33%Pn					
Test value		0.10	0.34	0.07	0.07
66%Pn	<u> </u>				
Test value		0.10	0.12	0.07	0.07
100%Pn	<u> </u>				
Test value		0.10	0.54	0.07	0.07

4.4	TABLE: Direct current injection						Р		
Rated output	Ratio of rated	Measure (A)	ed DC out	Coutput current between terminals Isolated transformer					Limit (A)
current (A)	output power (VA)	L1-L2	L1-L3	L2-L3	L1-N	L2-N	L3-N	? (Yes/No)	()
13	33%				0.016			No	0.130
13	66%				0.014			No	0.130
13	100%				0.016			No	0.130

Supplementary information:

N/A



Page 12 of 19

	IEC 61727		
Clause	Requirement + Test	Result - Remark	Verdict

1.6(a)	Table: harmonics ar	nd waveform dist	ortion (at 33%	Pn)	P
Harmonic	% of fundamental	Limits (% of fundamental)			Limits (% of fundamental)
02	0.184	1	03	0.649	4
04	0.112	1	05	0.123	4
06	0.127	1	07	0.068	4
08	0.053	1	09	0.148	4
10	0.065	0.5	11	0.122	2
12	0.027	0.5	13	0.062	2
14	0.026	0.5	15	0.106	2
16	0.040	0.5	17	0.092	1.5
18	0.064	0.5	19	0.077	1.5
20	0.043	0.5	21	0.100	1.5
22	0.049	0.5	23	0.072	0.6
24	0.046	0.5	25	0.092	0.6
26	0.025	0.5	27	0.098	0.6
28	0.042	0.5	29	0.101	0.6
30	0.037	0.5	31	0.103	0.6
32	0.029	0.5	33	0.088	0.6
THD	0.811	5			



Page 13 of 19

IEC 61727					
Clause	Requirement + Test	Result - Remark	Verdict		

1.6(b)	Table: harmonics ar	nd waveform disto	ortion (at 66%	Pn)	P	
Harmonic	% of fundamental	Limits (% of fundamental)			Limits (% of fundamental)	
2	0.070	1	3	0.420	4	
4	0.098	1	5	0.115	4	
6	0.071	1	7	0.129	4	
8	0.075	1	9	0.099	4	
10	0.061	0.5	11	0.077	2	
12	0.020	0.5	13	0.055	2	
14	0.015	0.5	15	0.050	2	
16	0.015	0.5	17	0.047	1.5	
18	0.032	0.5	19	0.043	1.5	
20	0.018	0.5	21	0.058	1.5	
22	0.025	0.5	23	0.046	0.6	
24	0.022	0.5	25	0.046	0.6	
26	0.014	0.5	27	0.043	0.6	
28	0.011	0.5	29	0.044	0.6	
30	0.013	0.5	31	0.041	0.6	
32	0.010	0.5	33	0.027	0.6	
THD	0.528	5				



Page 14 of 19

IEC 61727					
Clause	Requirement + Test	Result - Remark	Verdict		

4.6(c)	Table: harmonics ar	d waveform dist	ortion (at 100%	%Pn)	P
Harmonic	rmonic % of fundamental Limits (% of fundamental) Harmonic		% of fundamental	Limits (% of fundamental)	
02	0.033	1	03	1.074	4
04	0.102	1	05	0.525	4
06	0.048	1	07	0.339	4
08	0.031	1	09	0.319	4
10	0.047	0.5	11	0.130	2
12	0.024	0.5	13	0.088	2
14	0.008	0.5	15	0.066	2
16	0.020	0.5	17	0.097	1.5
18	0.029	0.5	19	0.058	1.5
20	0.016	0.5	21	0.045	1.5
22	0.018	0.5	23	0.049	0.6
24	0.022	0.5	25	0.043	0.6
26	0.012	0.5	27	0.032	0.6
28	0.009	0.5	29	0.052	0.6
30	0.008	0.5	31	0.037	0.6
32	0.012	0.5	33	0.021	0.6
THD	1.312	5			





IEC 61727					
Clause	Requirement + Test	Result - Remark	Verdict		

4.7	TABLI	E: Power fa	ctor					Р
		Input			0	utput		
No	Voltage (V d.c.)	Current (A d.c.)	Power (W)	Voltage (V a.c.)	Current (A a.c.)	Power (W)	Power factor	Rated output (V.A)
1	413.9	1.6	683	230.1	2.9	660	0.993(a) 0.993(b) N/A (c)	(20±5)%
2	411.8	2.5	1020	230.2	4.3	991	0.997(a) 0.997(b) N/A (c)	(30±5)%
3	409.3	3.3	1322	230.3	5.8	1322	0.998(a) 0.998(b) N/A (c)	(40±5)%
4	406.4	4.2	1699	230.4	7.2	1653	0.998(a) 0.999(b) N/A (c)	(50±5)%
5	403.0	5.1	2041	230.6	8.6	1984	0.999(a) 0.999(b) N/A (c)	(60±5)%
6	398.8	6.0	2383	230.7	10.0	2316	0.999(a) 0.999(b) N/A (c))	(70±5)%
7	393.3	7.0	2727	230.8	11.5	2648	0.999(a) 0.999(b) N/A (c)	(80±5)%
8	385.1	8.0	3070	230.9	12.9	2978	0.999(a) 0.999(b) N/A (c)	(90±5)%
9	359.2	9.5	3408	231.0	14.3	3303	0.999(a) 0.999(b) N/A (c)	(100±5)%

Supplementary information:

Power factor with "+" indicating leading and "-" indicating lagging


Each power stage has been maintained during 60 seconds for measurements with a sampling rate of 0.1 s

Values offered correspond with the 60s average measured with each corresponding stage.

Except for power factor measurements, where:

The value a) indicates the average of measured absolute PF values during each 60s stage of measurement.

The value b) indicates the maximum leading PF value measured during each 60s stage of measurement. The value c) indicates the maximum lagging PF value measured during each 60s stage of measurement.





IEC 61727					
Clause	Requirement + Test		Result - Remark	Verdict	

5.2.1 & 5.4	TAB	LE: Under-and	over-voltage	e trip settings	and recor	nection test	Р
(1) U	nder volta	ge disconnecti	on procedur	e			1
Rated output voltage (V)	Output power (VA)	Required min. voltage (V)	Value of PCE trip settings (V)	Ratio of decreased (V / s)	Interva I time (ms)	Measured tripped voltage (V)	Measured disconnectio n time (ms)
50 % Vn≤	V < 85 %	Vn				• •	
230	3300	195.5	195		2000	194.3	1615
230	3300	155	155		2000	154.4	1626
230	3300	117	117		2000	116.0	1668
V<50%Vn							
230	3300	114	114		100	113.8	41
(2) U	nder volta	ge reconnectio	n procedure				
	o of voltaç ecreased	ge rapidly (V / s)	Reconr	nection voltag	je (V)	Reconnection time (s)	
	37		231.8			78.8	
(3) O	ver voltag	je disconnectio	n procedure				
Rated output voltage (V)	Output power (VA)	Required max. voltage (V)	Value of PCE trip settings (V)	Ratio of increased (V / s)	Interva I time (ms)	Measured tripped voltage (V)	Measured disconnectio n time (ms)
110 % Vn	< V < 135	% Vn					
230	3300	253	255		2000	255.0	1630
230	3300	282	282		2000	282.3	40
230	3300	309	309		2000	308.9	6
135 % Vn:	≤V						
230	3300	312	312		50	312.9	3
(4) O	ver voltag	je reconnection	procedure				
Ratio of voltage rapidly decreased (V / s)		Reconnection voltage (V)			Reconnection time (s)		
	22		230			79.2	
Suppleme N/A	ntary infor	mation:			,		



Page 17 of 19

IEC 61727					
Clause	Requirement + Test	Result - Remark	Verdict		

5.2.2 & 5.4	TAB	SLE: Over/unde	er frequency t	rip settings a	nd reconn	ection test	Pass
(1) Uı		uency disconn	. ,				
Rated output frequency (Hz)	Output power (VA)	Required min. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of decreased (Hz / s)	Interva I time (ms)	Measured tripped frequency (Hz)	Measured disconnectio n time (ms)
50	3300	49	49		200	49	179
(2) Uı	nder frequ	uency reconne	ction proced	ure			
	of voltag creased (Reconnec	ction frequenc	cy (Hz)	Reconnection time (s)	
	2		50			79.0	
(3) O	ver freque	ency disconne	ction procedu	ıre			
Rated output frequency (Hz)	Output power (VA)	Required max. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of increased (Hz / s)	Interva I time (ms)	Measured tripped frequency (Hz)	Measured disconnectio n time (ms)
50	3300	51	51		200	51.1	174
(4) O	ver freque	ency reconnec	tion procedui	re			
Ratio of voltage rapidly decreased (Hz / s)		Reconnection frequency (Hz)			Reconnect	ion time (s)	
2			50			79.2	
Suppleme	ntary infor	mation:			-		
N/A							



Page 18 of 19

IEC 61727					
	Clause	Requirement + Test		Result - Remark	Verdict

5.3	Table: tested condition and run-on time					Р			
No.	PEUT (% of EUT rating)	Reactiv e load (% of normial)	Pac	Qac	Run-on time(ms)	Р _Е (W)	Actual Q _f	V _{DC} (d.c.V)	Which load is selected to be adjusted (R or L)
	Test condtion A								
1	100	100	0	0	408	2698	1.00	464.9	
2	100	100	-5	-5	324	2701	1.05	465.9	R/L
3	100	100	-5	0	364	2700	1.05	465.9	R
4	100	100	-5	+5	320	2701	1.02	466.1	R/L
5	100	100	0	-5	284	2698	1.03	465.0	L
6	100	100	0	+5	322	2689	0.98	460.3	L
7	100	100	+5	-5	318	2689	0.98	460.0	R/L
8	100	100	+5	0	332	2675	0.96	455.3	R
9	100	100	+5	+5	288	2696	0.95	462.9	R/L
10	100	100	-10	+10					R/L
11	100	100	-5	+10					R/L
12	100	100	0	+10					L
13	100	100	+10	+10					R/L
14	100	100	+10	+5					R/L
15	100	100	+10	0					R
16	100	100	+10	-5					R/L
17	100	100	+10	-10					R/L
18	100	100	+5	-10					R/L
19	100	100	+5	10					R/L
20	100	100	0	-10					L
21	100	100	-5	-10					R/L
22	100	100	-10	-10					R/L
23	100	100	-10	-5					R/L
24	100	100	-10	0					R/L
25	100	100	-10	+5					R/L





IEC 61727									
Clause Requirement + Test				Result - Remark					
	Test condtion B								
10	66	66	0	0	434	299.6	1.00	1783	
11	66	66	0	-5	292	299.5	1.02	1783	L
12	66	66	0	-4	352	299.4	1.02	1782	L
13	66	66	0	-3	338	298.1	1.01	1782	L
14	66	66	0	-2	340	298.6	1.01	1783	L
15	66	66	0	-1	308	299.6	1.00	1782	L
16	66	66	0	1	352	300.1	1.00	1782	L
17	66	66	0	2	344	298.9	0.99	1782	L
18	66	66	0	3	312	299.8	0.99	1783	L
19	66	66	0	4	360	298.0	0.99	1781	L
20	66	66	0	5	314	297.6	0.98	1780	L
21	66	66	0	6					L
				Test co	ndition C	1			
22	33	33	0	0	332	143.9	1.00	904	
24	33	33	0	-5	264	143.6	1.03	897	L
25	33	33	0	-4	318	144.1	1.02	897	L
26	33	33	0	-3	330	143.9	1.01	897	L
27	33	33	0	-2	316	144.2	1.01	899	L
28	33	33	0	-1	326	145.2	1.01	899	L
29	33	33	0	1	314	143.0	1.00	900	L
30	33	33	0	2	312	144.9	0.99	903	L
31	33	33	0	3	300	143.3	0.99	901	L
32	33	33	0	4	286	144.2	0.98	903	L
33	33	33	0	5	142	143.6	0.97	900	L
34	33	33	0	6					L

Remark:

For test condition A:

If any of the recorded run-on times are longer than the one recorded for the rated balance condition, then the non-shaded parameter combinations also require testing.

For test condition B and C:

If run-on times are still increasing at the 95 % or 105 % points, additional 1 % increments is taken until run-on times begin decreasing.

The compliances with these requirements are stated in the following test report:

IEC 62116: test report nº GZES191002576302

--- End of test report---



Page 1 of 12

IEC 61727:2004

Attachment I

(Pictures of the EUT and Electrical Schemes)






IEC 61727:2004

1 PICTURES

Front view 1(EVVO 2700TL-AV, EVVO 3000TL-AV, EVVO 3200TL-AV)



Back view 1(EVVO 2700TL-AV, EVVO 3000TL-AV, EVVO 3200TL-AV)








IEC 61727:2004

Front view 2 (EVVO 1100TL-AV, EVVO 1600TL-AV, EVVO 2200TL-AV)



Back view 2 (EVVO 1100TL-AV, EVVO 1600TL-AV, EVVO 2200TL-AV)





IEC 61727:2004

Internal view of enclosure (EVVO 2700TL-AV, EVVO 3000TL-AV, EVVO 3200TL-AV)



Internal view of enclosure (EVVO 1100TL-AV, EVVO 1600TL-AV, EVVO 2200TL-AV)






IEC 61727:2004

Front side of main board 1(EVVO 2700TL-AV, EVVO 3000TL-AV, EVVO 3200TL-AV)




Back side of main board 1(EVVO 2700TL-AV, EVVO 3000TL-AV, EVVO 3200TL-AV)






IEC 61727:2004

Front side of main board 2 (EVVO 1100TL-AV, EVVO 1600TL-AV, EVVO 2200TL-AV)




Back side of main board (EVVO 1100TL-AV, EVVO 1600TL-AV, EVVO 2200TL-AV)






IEC 61727:2004











IEC 61727:2004





Back view of RS 232 board







IEC 61727:2004

Connection interface



Side View








IEC 61727:2004

Grounding



Software Number (EVVO 2700TL-AV, EVVO 3000TL-AV, EVVO 3200TL-AV)








IEC 61727:2004

Software Number (EVVO 1100TL-AV, EVVO 1600TL-AV, EVVO 2200TL-AV)



Software version






Page 12 of 12

IEC 61727:2004

2 ELECTRICAL SCHEMES





Page 1 of 4

IEC 61727:2004

Attachment II


(Testing information)



Page 2 of 4

IEC 61727:2004

1 TESTING CIRCUIT



Current and voltage clamps have been connected to the inverter input/output for all the tests.

All the tests and checks have been performed in accordance with the reference standard under testing.





IEC 61727:2004

2 TESTING EQUIPMENT

Fro m	No.	Equipment Name	Model No.	Equipment No.	Calibration Date	Equipment calibration due date
	1	Digital oscilloscope	DS05014A	MY500702 66	2019-02-13	2020-02-12
	2	Voltage probe	SI-9110	111541	2019-02-13	2020-02-12
	3	Voltage probe	SI-9110	152627	2019-02-13	2020-02-12
	4	Voltage probe	SI-9110	111134	2019-02-13	2020-02-12
<u>a</u>	5	Power analyzer	WT3000	91N610888	2019-02-13	2020-02-12
Sofarsolar	6	Current probe	i1000s	29503223	2019-02-13	2020-02-12
S	7	Current probe	i1000s	30413448	2019-02-13	2020-02-12
	8	Current probe	CP5150	C15015000 8	2019-02-13	2020-02-12
	9	Temperature & Humidity meter	TH101B	201030245 220	2019-02-13	2020-02-12
	Temperature 10 & Humidity Chamber		HGTP -225R	HG130308 01	2019-02-13	2020-02-12
SGS	11	True RMS Multimeter	Fluke / 289C	GZE012-53	2019-02-26	2020-02-25

Items	Specifications		
1) PV array simulator			
a) Voltage range	0 – 1000Vdc (0.01V step)		
b) Current range	0 – 40A (0.01A step)		
2) AC power source			
a) Output wiring	Three phase		
b) Output capacity	30KVA		
c) Output voltage	10-300Vrms		
d) Output frequency	45-65Hz		
e) Voltage stability	<u>+</u> 100ppm/℃		
f) Output voltage distortion	0.05% max.		
3) Digital meter			
a) Voltage range	0 – 1000Vdc, 0 – 600Vrms		
b) Current range	0 – 30A		



Page 4 of 4

IEC 61727:2004

c) Frequency range (accuracy)	0.2%				
d) Measurement items	Voltage (V) Current (A) Active power (W)				
	Reactive power (Var)				
	Volt-ampere (VA)				
	Power factor (PF)				
	Frequency (Hz)				
	Electric energy (Wh)				
4) Waveform recorder					
a) Sampling speed	1M/s				
b) Recording device	Memory record and USB reading				
c) Time accuracy	<u>+</u> 500ppm				
5) AC load					
a) Resistive load	Maximum voltage: 300Vrms				
	Current range: 0 – 100A				
	Capacity: 30KW				
b) Inductive load	Maximum voltage: 300Vrms				
	Current range: 0 – 100A				
	Capacity: 30KVA				
c) Capacitive load	Maximum voltage: 300Vrms				
	Current range: 0 – 100A				
	Capacity: 30KVA				

3 MEASUREMENT UNCERTAINTY

Magnitude	Uncertainty		
Voltage measurement	±1.5 %		
Current measurement	±2.0 %		
Frequency measurement	±0.2 %		
Time measurement	±0.2 %		
Power measurement	±2.5 %		
Phase Angle	±1°		
Temperature	±3° C		

Note1: Measurements uncertainties showed in this table are maximum allowable uncertainties. The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the petitioner.

Note2: Where the standard requires lower uncertainties that those in this table. Most restrictive uncertainty has been considered.



Attachment III

Report Nº GZES191002576301

IEC 61727:2004

Page 1 of 21

Attachment III

(GRAPHS AND SCREENSHORTS OF TEST RESULTS)



IEC 61727:2004


Flickers

The measurements of voltage fluctuations have been measured at 33 %, 66% and 100 % of the nominal power value of the inverter.

As it can be seen in the next screenshots, this test has two steps:


- 1.Starting operation
- 2.Stopping operation

The values took of Dmax of the two steps.





IEC 61727:2004



As it can be seen in the next screenshots is running operation. The values took of Pst and Plt are the most unfavorable of the twelve steps.

		Ru	inning operati	on				
33% Pn								
Flicker Mode Uover:== Iover:==						OGAWA ◆		
	Count Interval	12/12 10m00s/10m00s			0s			
Element Volt Rai	1 nae 300V/5	Un -	Elementi lud	nomont: Dace				
Un (Se								
Freq(U1)								
		1907 1909(1)						
	dc[%]	dmax[%]	d(t)[ms]	Pst	P1t			
Limit	3.30	4.00	500	1.00	0.65			
			3.30(%)		N:12			
No. 1	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass				
2	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass				
3	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass				
4	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass				
5	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass				
6 7	0.00 Pass 0.00 Pass	0.00 Pass 0.00 Pass	0 Pass	0.07 Pass 0.07 Pass				
1 1	0.00 Pass		0 Pass	0.07 Pass				
8 9		0.00 Pass	0 Pass					
10	0.00 Pass 0.00 Pass	0.00 Pass 0.00 Pass	0 Pass	0.07 Pass 0.07 Pass				
11	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass				
12	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass 0.07 Pass				
			0 Pass		0.07 Pass			
Result	Pass	Pass	Pass	Pass	U.U/ Pass			
date 360	าก		2	019/04/25 13	:27:59			



Attachment III

Report Nº GZES191002576301

Page 4 of 21

IEC 61727:2004

66% Pn

Uover:= = = = Iover:= = = = Flicker Mode

YOKOGAWA 💠 Flicker:Complete 2:00:00

Count Interval 12/12 ■ 10m00s/10m00s

Element Volt Range Un (Set)

Freq(U1)

300V/50Hz 230.000 V 50.000 Hz Fotal Judgement: Pass (Element1)

	dc[%]	dmax[%]	d(t)[ms]	Pst	P1t
Limit	3.30	4.00	500	1.00	0.65
			3.30(%)		N:12
No. 1	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
2	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
3	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
4	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
5	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
6	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
7	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
8	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
9	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
10	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
11	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
12	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
Result	Pass	Pass	Pass	Pass	0.07 Pass

Update 3600

2019/04/25 18:19:10

100% Pn

Flicker Mode

Freq(U1)

Uover:= = = = Iover:= = = =

YOKOGAWA ◆ Flicker:Complete 2:00:00

Count

■ 12/12 ■ 10m00s/10m00s

Interval 1 Element Volt Range Un (Set)

300V/50Hz

Element1 Judgement: Pass Total Judgement: Pass (Element1)

230.000 V 49.999 Hz

	dc[%]	dmax[%]	d(t)[ms]	Pst	P1t
Limit	3.30	4.00	500	1.00	0.65
1 1			3.30(%)		N:12
No. 1	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
2	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
3	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
4	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
5	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
6	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
7	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
8	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
9	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
10	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
11	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
12	0.00 Pass	0.00 Pass	0 Pass	0.07 Pass	
Result	Pass	Pass	Pass	Pass	0.07 Pass


Update 3600

2019/04/25 16:16:56

Page 5 of 21

IEC 61727:2004


Direct current injection




Page 6 of 21

IEC 61727:2004

Harmonics and waveform distortion








Page 7 of 21

IEC 61727:2004

Power factor







Page 8 of 21

IEC 61727:2004


Under-and over-voltage trip settings and reconnection test




Attachment III Report N° GZES191002576301









Page 11 of 21




Attachment III Report N° GZES191002576301




Attachment III Report N° GZES191002576301




Page 14 of 21




Page 15 of 21




Page 16 of 21



Attachment III Report N° GZES191002576301








Page 18 of 21

IEC 61727:2004

Over/under frequency trip settings and reconnection test









Report Nº GZES191002576301

Attachment III

Page 19 of 21











Attachment III Report N° GZES191002576301





Attachment III Report N° GZES191002576301

