

Name of Testing Laboratory : SGS TECNOS S.A. (Laboratory of electrical tests)
Applicant : SGS TECNOS S.A. (Certification Body)
Hired by : **EVOLVE ENERGY GROUP CO., LIMITED**
Address : RM 702, 7/F FU FAI COMM CTR 27 HILLIER ST SHEUNG WAN, HK

Date (s) of performance of tests : 30/10/2017 till 20/11/2017 and 24/04/2019 till 06/05 2019

Test item description..... : Solar Grid-tied Inverter (Single Phase inverter)
Status and date of receipt : N/A
Manufacturer : **EVOLVE ENERGY GROUP CO., LIMITED**

Trade Mark : 




Model / Type Reference... : **EVVO 6000TLG2**
Ratings..... : DC input: 90-580V, 11/11A.
 AC output: 230V, 50Hz, 27.3A, 6000VA
 Serial Number: ZG1ES060H61001
 ZH1ES160H9S999 for spot-check test
 Firmware version: V0.22

Applied Specifications : Standard:
 IEC 61727 :2004

Test Results : The test results obtained refer only to the samples tested, which are the object of this report, considering the most unfavorable values of the test and verifications carried out. The uncertainties of measurement associated to the quantities determined during the tests are in the laboratory available to the applicant.

Conclusion : According to the test results, the sample tested is found in **CONFORMANCE** with the requirements stated in the specifications applied

Madrid, Jun18th, 2019

Tested by:	Reviewed and Approved by:
Project Engineer	Technical Reviewer
 ROGER HU	  JACOBO TÉVAR

The present Test Report, consisting of 1 page and the TRF 2217 / 1094 – 3 – M2 including 22 pages and 32 pages attachments, is a co-report of test report 2217 / 1094 – 3–M1 and shall not be reproduced partially without the approval of SGS.

LABORATORY OF ELECTRICAL TESTS: Phone: 913 138 000 Fax. 913 318 093

SGS Tecnos S.A. | c/ Trespaderne, 29 28042 Madrid | t (34) 91 313 80 00 | f (34) 91 313 80 93 | www.sgs.es

Miembro del Grupo SGS (Société Générale de Surveillance)