


Name of Testing Laboratory : SGS TECNOS S.A. (Laboratory of electrical tests)
Applicant : SGS TECNOS S.A. (Certification Body)
Hired by : EVOLVE ENERGY GROUP CO., LIMITED
Address : RM 702, 7/F FU FAI COMM CTR 27 HILLIER ST SHEUNG WAN, HK

Date (s) of performance of tests : 05/11/2017 till 06/11/2017

Test item description : Solar Grid-tied Inverter (Single Phase inverter)
Status and date of receipt : N/A
Manufacturer : EVOLVE ENERGY GROUP CO., LIMITED

Trade Mark : 




Model / Type Reference... : EVVO 6000TLG2
Ratings..... : DC input: 90-580V, 11/11A.
 AC output: 230V, 50Hz, 27.3A, 6000VA
 Serial Number: ZG1ES060H61001
 Firmware version: V0.22

Applied Specifications : Standard:
 IEC 62116: 2014
 Except sub-clause d) of Table 5 of point 6.1.

Test Results : The test results obtained refer only to the samples tested, which are the object of this report, considering the most unfavorable values of the test and verifications carried out. The uncertainties of measurement associated to the quantities determined during the tests are in the laboratory available to the applicant.

Conclusion : According to the test results, the sample tested is found in **CONFORMANCE** with the requirements stated in the specifications applied

Madrid, Jun 18th, 2019

Tested by: Project Engineer	Reviewed and Approved by: Technical Reviewer
 ROGER HU	  JACOBO TÉVAR

The present Test Report, consisting of 1 page and the TRF 2217 / 1094 – 1 – M2 including 14 pages and 37 pages attachments, is a co-report of test report 2217 / 1094 – 1 – M1 and shall not be reproduced partially without the approval of SGS.

LABORATORY OF ELECTRICAL TESTS: Phone: 913 138 000 Fax. 913 318 093

SGS Tecnos S.A. c/ Trespaderne, 29 28042 Madrid t (34) 91 313 80 00 f (34) 91 313 80 93 www.sgs.es

Miembro del Grupo SGS (Société Générale de Surveillance)