

TEST REPORT

Photovoltaic systems – Power conditioners – Procedure for measuring efficiency

Report reference number:	PV190627N026-2
Date of issue	2019-07-23
Total number of pages	23
Testing laboratory name:	Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch
Address :	No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China
Applicant's name:	EVOLVE ENERGY GROUP CO., LIMITED
Address:	RM 702, 7/F FU FAI COMM CTR 27 HILLIER ST SHEUNG WAN, HK
Test specification	
Standard:	IEC 61683:1999; EN 61683:2000; DIN EN 61683:2000
Certificate:	Certificate of compliance
Test report form number	IEC61683
Master TRF:	Bureau Veritas Consumer Products Services Germany GmbH
Test item description	PV Grid inverter
Trademark:	EVIVO
Model / Type:	EVVO 50000TL3P, EVVO 60000TL3P, EVVO 70000TL3P-HV
This report is governed by, and incorporates by reference, CPS Condit business/cps/about-us/terms-conditions/and is intended for your exclus- only with our prior written permission. This report sets forth our finding: the quality or characteristics of the lot from which a test sample was ta and the results thereof based upon the information that you provided to report to notify us of any material error or omission caused by our negl address the issue you wish to raise. A failure to raise such issue within correctness of the report contents.	tions of Service as posted at the date of issuance of this report at http://www.bureauveritas.com/home/about-us/our-sive use . Any copying or replication of this report to or tor any other person or entity, or use of our name or trademark, is permitted s solely with respect to the test samples identitied herein. The results set forth in this report are not indicative or representative of ken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you o us. Measurement uncertainty is only provided upon request for accredited tests. You have 60 days from date of issuance of this igence or if you require measurement uncertainty; provided, however, that such notice shall be in writing and shall specifically the prescribed time shall constitute you unqualified acceptance of the completeness of this report, the tests conducted and the

No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 1 of 23



Ratings:	EVVO 50000TL3P	EVVO 60000TL3P	EVVO 70000TL3P-HV
Full load MPP DC voltage range [V]:	600-800		700-800
Input DC voltage range [V]:	250-950, Max. 1000		
Input DC current [A]:	Max. 40/30/30	Max. 4	0/40/40
Output AC voltage [V]:	3~/N/PE, 230/	400Vac, 50Hz	3~/PE, 480Vac, 50Hz
Output AC current [A]:	Max. 80	Max	к. 90
Nominal output power [W]	50000	60000	70000
Max. output power [VA]:	50000	60000	75000
Testing Location:	Shenzhen Academy o	f Metrology & Quality	Inspection
Address:	No. 4 Tongfa Rd.,Nans	han, Shenzhen, China	
Tested by (name and signature):	Dora Zhang	D	ova
Approved by (name and signature):	James Huang	J	type
Manufacturer's name:	EVOLVE ENERGY GR	OUP CO., LIMITED	
Factory address:	1F - 6F, Building E, No Village, Fenggang Tow	. 1 JinQi Road, Bihu Ind n, Dongguan City	ustrial Park, Wulian

Document History			
Date	Internal reference	Modification / Change / Status	Revision
2019-07-23	Dora Zhang	This is a copy test report	
Supplementary information:			



Test items particulars			
Equipment mobility:	Permanent connection		
Operating condition	Continuous		
Class of equipment:	Class I		
Mass of equipment [kg]:	EVVO 50000TL3P, EVVO 60000TL3P: 68kg; EVVO 70000TL3P-HV: 70kg		
Test case verdicts			
Test case does not apply to the test object:	N/A		
Test item does meet the requirement:	P(ass)		
Test item does not meet the requirement:	F(ail)		
Testing			
Date of receipt of test item:	2018-12-20		
Date(s) of performance of test:	2018-12-20 to 2019-02-21		
General remarks:			
The test result presented in this report This report must not be reproduced in laboratory.	relate only to the object(s) tested. part or in full, without the written approval of the issuing testing		
"(see Annex #)" refers to additional info "(see appended table)" refers to a table	ormation appended to the report. e appended to the report.		
The test results refer to the original tes Ltd. Dongguan Branch, dated on Mar.	t report PV181220N074-2 issued by Bureau Veritas Shenzhen Co., 01, 2019.		
Throughout this report a comma is use	d as the decimal separator.		
This Test Report consists of the foll	owing documents:		
1. Test Results			
2. Annex No. 1 – Datasheet of th	e unit		
3. Annex No. 2 – Pictures of the u	unit		
4. Annex No. 3 – Test equipment	list		

Copy of marking plate:

EVVO Solar Grid-tied Inverter

Model No:	EVVO 50000TL3P
Max.DC Input Voltage	1000V
Operating MPPT Voltage Rang	e 250~950V
Max.InputCurrent	40A/30A/30A
Max. PV lsc	48A/36A/36A
Nominal Grid Voltage	3/N/PE,400Vac
Max.Output Current	80A
Nominal Grid Frequency	50/60Hz
Nominal Output Power	50000W
Max.Output Power	50000VA
Power Factor >0.9	9(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperature Rang	ge -25℃~+60℃
Protective Class	Class I
Factory - Shenzhen China	
Manufacturer : EVOLVE ENERGY (Address : RM 702, 7/F FU FAI COM SHEUNG WAN, HK Global Head Quarters 371 Sidco Industrial Estate Chennai 600098 India VDE0126-1-1, VDE-AR-N4105,G96 IEC62116,AS4777	GROUP CO., LIMITED M CTR 27 HILLIER ST 9,IEC61727,

EVNO	Solar Grid-tied Inverter
Model No:	EVVO 60000TL3P
Max.DC Input Voltage	1000V
Operating MPPT Voltag	e Range 250~950V
Max. InputCurrent	40A/40A/40A
Max. PV lsc	48A/48A/48A
Nominal Grid Voltage	3/N/PE,400Vac
Max.Output Current	90A
Nominal Grid Frequer	cy 50/60Hz
Nominal Output Powe	r 60000W
Max.Output Power	60000VA
Power Factor	>0.99(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperatu	re Range -25°C~+60°C
Protective Class	Class I
Factory - Shenzhen C	hina
Manufacturer : EVOLVE EI Address :RM 702, 7/F FU F SHEUNG WAN, HK Global Head Quarters 371 Sidco Industrial Estate Chennai 600098 India VDE0126-1-1,VDE-AR-N4 IEC62116,AS4777	NERGY GROUP CO., LIMITED FAI COMM CTR 27 HILLIER ST 105,G99,IEC61727,

EV_NO

Solar Grid-tied Inverter

Model No:	EVVO 70000TL3P-HV
Max.DC Input Voltage	1000V
Operating MPPT Voltage R	lange 250~950V
Max. InputCurrent	40A/40A/40A
Max. PV lsc	48A/48A/48A
Nominal Grid Voltage	3/PE,480Vac
Max.Output Current	90A
Nominal Grid Frequency	50/60Hz
Nominal Output Power	70000W
Max.Output Power	75000VA
Power Factor >	0.99(adjustable+/-0.8)
Ingress Protection	IP65
Operating Temperature F	Range -25°C~+60°C
Protective Class	Class I
Factory - Shenzhen Chin	a
Manufacturer : EVOLVE ENER Address : RM 702, 7/F FU FAI (SHEUNG WAN, HK Global Head Quarters 371 Sidco Industrial Estate Chennai 600098 India VDE0126-1-1, VDE-AR-N4105 IEC62116 AS4777	GY GROUP CO., LIMITED COMM CTR 27 HILLIER ST ,G99,IEC61727,
III 🛆 CE 🦄	0. 1 1

Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 4 of 23





General product information:

The Solar Grid-tied inverter converts DC voltage into AC voltage.

The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and two relays for each phases in series. This assures that the opening of the output circuit will also operate in case of one error. Block diagram as following:



Figure 1 Block diagram

The internal control is redundant built. It consists of master DSP (UC20) and slave DSP (UC73).

The master DSP (UC20) can control the relays, measures voltage, and frequency, AC current with injected DC, array insulation resistance and residual current and the RCMU circuit before each start up.

The slave DSP (UC73) is using for sample the grid voltage, frequency, DC voltage, current and residual current, also can open the relays independently and communicate with master DSP (UC20) each other.

The grid voltage is measured before the relays. The voltage between polarity is calculated. The voltage signals are sent to both DSP. In addition this signal is used for the frequency measurement.

The unit provides two relays in series in each phase. The relays are tested before each start up. Each DSP switch off each relays.

The current is measured by a current sensor. The AC current signal and the injected DC current signal are sent to the main DSP (UC20). The main DSP (UC20) tests and calibrates before each start up all current sensors.

The RCMU is located at the AC output. The RCMU is tested before each start up by the main DSP (UC20). While unit working, if a high level residual current occurs, the RCMU will give signal to DSP assuring that unit grid-off from AC mains.

The model EVVO 70000TL3P-HV is identical to EVVO 50000TL3P and EVVO 60000TL3P except the numbers of the input PV terminals, Sic diodes, Sis MOS, BOOST inductors and INV inductors, the output ac voltage and output power derated by software.

The product was tested on:

Hardware version: V1.00 Software version: V2.00

Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 5 of 23



IEC 61683:1999

Clause/§	Requirement	Remark	Verdict

1	Scope
	(measuring the efficiency of power conditioners used in stand-alone and utility-interactive photovoltaic systems)

2	Normative references
	IEC 60146-1-1:1991,

3	Definitions
	3.1 rated output efficiency
	3.2 partial output efficiency
	3.3 energy efficiency
	3.4 efficiency tolerance
	3.5 PV array simulator
	3.6 no-load loss
	3.7 standby loss
	3.8 maximum power point tracking (MPPT)

4	Efficiency measurement conditions	Considered.	Р
	Efficiency shall be measured under the matrix of conditions as described in the following clauses and table 1. Specific conditions may be excluded by mutual agreement when those conditions are outside the manufacturer's allowable operating range. The resulting data shall be presented in tabular form and may also be presented graphically.	See below.	Ρ
4.1	DC power source for testing		Р
	For power conditioners operating with fixed input voltage, the d.c. power source shall be a storage battery or constant voltage power source to maintain the input voltage.		N/A
	For power conditioners that employ maximum power point tracking (MPPT) and shunt-type power conditioners, either a photovoltaic array or a photovoltaic array simulator shall be utilized.	Photovoltaic array simulator used.	Ρ
4.2	Temperature		Р
	All measurements are to be made at an ambient temperature of 25 °C \pm 2 °C.	25°C	Р
4.3	Output voltage and frequency		Р



	IEC 61683:1999				
Clause/§	Requirement	Remark	Verdict		
	The output voltage and frequency shall be maintained at the manufacturer's stated nominal values.	EVVO 50000TL3P, EVVO 60000TL3P: 230Vac, 50Hz; EVVO 70000TL3P-HV: 480Vac, 50Hz;	Р		
4.4	Input voltage		Р		
	manufacturer's minimum rated input voltage	250Vdc	Р		
	the inverter's nominal voltage or the average of its rated input range	EVVO 50000TL3P, EVVO 60000TL3P: 700Vdc; EVVO 70000TL3P-HV: 750Vdc	Р		
	90 % of the inverter's maximum input voltage	900Vdc	Р		
4.5	Ripple and distortion		Р		
	Record input voltage and current ripple for each measurement	The ripple of the input voltage had no influence on the measurements. (see appended table)	P		
4.6	Resistive loads/utility grid		Р		
	Grid-connected inverters: measure the efficiency for power levels of 10 %, 25 %, 50 %, 75 %, 100 % and 120 %	The efficiency measurement was performed at 10 %, 25 %, 50 %, 75 %, 100 % because the unit does not provide overload function.	Ρ		
	Stand-alone inverters: measure the efficiency for power levels of 5 %, 10 %, 25 %, 50 %, 75 %, 100 % and 120 %	Grid-connected inverters.	N/A		
4.7	Reactive loads		N/A		
	Stand-alone inverters: efficiency with a load which provides a power factor equal to the manufacturer's specified minimum level (or 0,25, whichever is greater) and at power levels of 25 %, 50 % and 100 % of rated VA	Grid-connected inverters.	N/A		
	Stand-alone inverters: efficiency with power factors of 0,5 and 0,75 (do not go below the manufacturer's specified minimum PF) and power levels of 25 %, 50 %, and 100 % of rated VA		N/A		
4.8	Resistive plus non-linear loads		N/A		
	Stand-alone inverters: efficiency with a fixed non- linear load (total harmonic distortion (THD) = (80 ± 5) %) equal to (25 ± 5) % of the inverter's rated VA plus sufficient resistive load in parallel to achieve a total load of 25 %, 50 % and 100 % of rated VA	Grid-connected inverters.	N/A		
	Stand-alone inverters: efficiency with a fixed non- linear load equivalent to (50 ± 5) % of the inverter's rated VA plus sufficient resistive load in parallel to achieve a total load of 50 % and 100 % of rated VA		N/A		



IEC 61683:1999

Clause/§	Requirement	Remark	Verdict
4.9	Complex loads		N/A
	Stand-alone inverters: efficiency with a fixed non- linear load (THD = (80 ± 5) %) equal to (50 ± 5) % of the inverter's rated VA plus a sufficient reactive load (PF = 0,5) in parallel to achieve a total load of 50 % and 100 % of rated VA.	Grid-connected inverters.	N/A

5.	Efficiency calculations	See below.	Р
5.1	Rated output efficiency		Р
	Rated output efficiency shall be calculated from measured data as follows:	Considered.	Р
	$\eta_{R} = (P_{o} / P_{i}) \times 100$		
5.2	Partitial output efficiency		N/A
	Partial output efficiency shall be calculated from measured data as follows: $\eta_{par} = (P_{op} / P_{ip}) \times 100$	No derating during testing.	N/A
5.3	Energy efficiency		Р
	Energy efficiency shall be calculated from measured data as follows: $\eta_E = (W_o / W_i) \times 100$	Considered.	Р
5.4	Efficiency tolerances		Р
	When an efficiency value has been guaranteed, the tolerance of this value shall be within: $-0,2(1-\eta)\eta$ (%)	Considered.	Р

6.	Efficiency test circuits	See below.	Р
6.1	Test circuits	Considered.	Р
	See figures 1a and 1b	Figure 1b used.	Р
6.2	Measurement procedure	Considered.	Р
	a) Efficiency is calculated with equation (1) or (2) using measured P _i , P _o or P _{ip} , P _{op} . DC input power P _i , P _{ip} can be measured by wattmeter W ₁ , or determined by multiplying the d.c. voltmeter V ₁ and d.c. ammeter A ₁ readings. Output power P _o , P _{op} is measured with wattmeter W ₂ .	Considered.	Ρ
	b) DC input voltage, which is measured by d.c. voltmeter V_1 , shall be varied in the defined range where the output current, which is measured with a.c. ammeter A_2 , is varied from low output to the rated output.	Considered.	Ρ



Г

	IEC 61683:1999				
Clause/§	Requirement	Remark	Verdict		
	c) An average indicating instrument shall be used for the d.c. voltmeter and d.c. ammeter. A true r.m.s. type of indicating instrument shall be used for the a.c. voltmeter and a.c. ammeter. The d.c. wattmeter W_1 shall be a d.c. measuring type. The wattmeter W_2 shall be an a.c. or d.c. measuring type according to the output.	Considered.	Ρ		
	d) Power factor (PF in per cent) can be measured by a power factor meter PF, or calculated from the readings of V ₂ , A ₂ , W ₂ and as follows: PF = $(W_2/(V_2 \times A_2)) \times 100$	Considered.	Р		
	e) Each meter may be an analogue type or a digital type. The measurement accuracy shall be better than \pm 0,5 % of the full-scale value for each power measured. Digital power instruments for W1 and W2 are also recommended.	Digital measurement devices were used for testing. The accuracy of the measurement devices fulfills the requirements.	Ρ		
	f) An MPPT dynamically adjusts the input voltage so as to maximize the output power. In principle, the monitoring equipment shall sample all of the electrical parameters, such as input voltage and current, output power and current, within the update period of the MPPT. If the MPPT and input source (PV array or PV array simulator) interact in such a way that the input voltage varies by less than 5 %, then averaging of readings is acceptable. The averaging period shall be 30 s or longer.	The dynamic MPPT was deactivated, the 60s average was used anyway.	Ρ		

7.	Loss measurement	See below.	Р
7.1	No-load loss		Р
	Stand-alone inverters: reading of d.c. input voltage, output voltage and frequency is given with meters V ₁ , V ₂ and F respectively in figure 1a, and shall be adjusted to the rated values.	Grid-connected inverters.	N/A
	Utility-interactive inverters: reading of d.c. input voltmeter V ₁ , a.c. output voltmeter V ₂ and frequency meter F in figure 1b shall be adjusted to meet the specified voltages and frequency.	See appended table.	Р
7.2	Standby loss		Р
	Stand-alone inverters: Consumption of utility power when the power conditioner is not operating but is under standby condition.	No such inverters.	N/A
	Utility-interactive inverters: consumption from the d.c. source when the power conditioner is not operating but is under standby condition.	See appended table.	Р

Annex A	Power conditioner de	escription (informative)	See below		Р
	A power conditioner is	defined in IEC 61277	Figure A.2		Р
Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch		No. 34, Chenwulu Section, Gua Houjie Town, Dongguan City, G 523942, China Page 9 of 23	antai Rd., uangdong	Tel: +86 Fax: +86 Email: <u>customerservice.dg</u> @cn.l TEST REPORT IE	769 8998 2098 769 8599 1080 bureauveritas.com C61683 VER.0



IEC 61683:1999

Clause/§	Requirement	Remark	Verdict

Annex B	Power efficiency and conversion factor (informative)	See below.	Р
	There are two types of efficiencies shown in IEC 60146-2; one is a power efficiency, the other is a conversion factor. Power efficiency is defined as the ratio of active output power and active input power. Conversion factor is the ratio between output and input fundamental power levels.	Power efficiency used.	Ρ

Annex C	Weighted-average energy efficiency (informative)	See below.	Р	
	The energy of a power conditioner depends on both the irradiance profile and the load profile. The energy efficiency of a power conditioner shall be calculated by the ratio of the output to the input energy actually measured over a certain period	Considered.	Ρ	
C.1	ηw⊤ of power conditioner for utility-interactive PV systems	EVVO 50000TL3PL: 700Vdc, T1=T2=T3=T4: 98,09%; EVVO 60000TL3P: 700Vdc, T1=T2=T3=T4: 98,18%; EVVO 70000TL3P-HV: 750Vdc, T1=T2=T3=T4: 98,26%;	Ρ	
	Utility-interactive PV systems, which have no storage and for which reverse-power flow is accepted, are described. In this case, d.c. power generated by the PV array is supplied direct into the power conditioner (PC). Almost all of the input power to the PC is converted to a.c. power. A part of it is dissipated as the PC loss.	Considered.	Ρ	
C.2	η_{WT} of power conditioner for stand-alone PV systems	Grid-connected inverters.	N/A	
	In stand-alone PV systems with a storage subsystem, power generated from the PV array is stored and stabilized by the batteries. DC power is converted into regulated d.c. power or constant-voltage and constant-frequency a.c. power by a power conditioner (PC) and supplied to the load. In this case, some fraction of the generated power is dissipated as a loss in the batteries and power conditioner.		N/A	

Annex D	Derivation of efficiency tolerance in table 2	Considered.	Р
	(informative)		





No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 11 of 23





No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 12 of 23



No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 13 of 23



4.5 Input	ripple and dist	ortion				Р
EVVO 50000T	L3P					
				Power Level		
Ripple	voltage	10%	25%	50%	75%	100%
(*	P P)	5000W	12500W	25000W	37500W	50000W
V _{min}	600	19,26 V	9,63 V	7,70 V	8,67 V	5,92 V
Vnominal	700	16,09 V	11,,29 V	11,16 V	9,07 V	6,66 V
V _{max. mppt}	800	14,84 V	18,53 V	9,22 V	9,59 V	8,13 V
Vmppt (90%)	720	19,92 V	16,15 V	10,62 V	8,40 V	7,68 V
V _{max (90%)}	900	15,48 V	8,18 V	6,22 V	0,02 V	
				Power Level		
Ripple	current	10%	25%	50%	75%	100%
	рр)	5000W	12500W	25000W	37500W	50000W
V _{min}	600	0,29 A	0,34 A	0,55 A	0,93 A	0,85 A
Vnominal	700	0,16 A	0,29 A	0,59 A	0,75 A	0,71 A
Vmax. mppt	800	0,11 A	0,36 A	0,38 A	0,57 A	0,66 A
Vmppt (90%)	720	0,21 A	0,42 A	0,53 A	0,62 A	0,78 A
Vmax (90%)	900	0,11 A	0,13 A	0,18 A	0,04 A	

No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 14 of 23



EVVO 60000TL3P							
Ripple voltage (Vp-p)		Power Level					
		10%	25%	50%	75%	100%	
		6000W	15000W	30000W	45000W	60000W	
V _{min}	600	13,77 V	11,25 V	7,78 V	7,52 V	8,56 V	
Vnominal	700	20,31 V	12,84 V	9,41 V	9,67 V	10,19 V	
Vmax. mppt	800	22,27 V	14,43 V	10,36 V	9,11 V	8,92 V	
Vmppt (90%)	720	16,20 V	9,54 V	9,82 V	7,40 V	9,51 V	
Vmax (90%)	900	15,45 V	9,87 V	8,48 V	0,02 V		
		Power Level					
Ripple	Ripple current		25%	50%	75%	100%	
(Αρ-ρ)		6000W	15000W	30000W	45000W	60000W	
V _{min}	600	0,25 A	0,47 A	0,66 A	0,96 A	1,50 A	
Vnominal	700	0,25 A	0,41 A	0,59 A	0,93 A	1,26 A	
V _{max. mppt}	800	0,20A	0,35 A	0,50 A	0,68 A	0,87 A	
V _{mppt (90%)}	720	0,19 A	0,28 A	0,61 A	0,66 A	1,16 A	
V _{max (90%)}	900	0,10 A	0,18 A	0,32 A	0,04 A		

No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 15 of 23



EVVO 70000TL3P-HV							
Ripple voltage (Vp-p)		Power Level					
		10%	25%	50%	75%	100%	
		7000W	17500W	35000W	52500W	70000W	
V_{min}	700	21,99V	10,38V	8,18V	7,69V	10,55V	
Vnominal	750	22,19V	12,60V	8,56V	9,73V	8,85V	
Vmax (90%)	800	24,49V	12,11V	8,89VV	7,83V	10,13V	
Vmppt (90%)	720	15,32V	11,53V	9,73V	7,19V	9,06V	
Vmax. mppt	900	13,82V	9,14V	5,76V			
		Power Level					
Ripple	Ripple current		25%	50%	75%	100%	
(Ab-b)		5000W	12500W	25000W	37500W	50000W	
V_{min}	700	0,34A	0,40A	0,61A	0,85A	1,57A	
V _{nominal}	750	0,25A	0,39A	0,56A	0,94A	1,16A	
V _{max (90%)}	800	0,27A	0,34A	0,51A	0,65A	1,11A	
V _{mppt (90%)}	720	0,21A	0,40A	0,69A	0,76A	1,30A	
V _{max. mppt}	900	0,14A	0,25A	0,25A			

Report No.: PV190627N026-2



Annex 1 Datasheet of the unit

Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 17 of 23



9.1 Input parameter (DC)

Parameter	EVVO 50000TL3P	EVVO 60000TL3P	EVVO 70000TL3P-HV			
Max. input voltage	1000V					
Start-up input voltage	350V (+/-1v)					
Number of independent MPPT	3					
Number of DC inputs	4/3/3	4/3/3 4/4/4				
Input range with Full power operation with 2 MPPT parallel	530V-800V	530V-800V	660V-800V			
Max DC power for single MPPT	22000(530V-800V) 16000(530V-800V) 16000(530V-800V)	22000(530V-800V) 22000(530V-800V) 22000(530V-800V)	26000(660V-800V) 26000(660V-800V) 26000(660V-800V)			
Operating input volt range	250V-960V					
Max. input MPPT current	40A/30A/30A 40A/40A/40A		10A/40A			
Input short circuit current for each MPPT	48A/36A/36A	48A/48A/48A				
Overvoltage category of input	П					

9.2 Output parameter (AC)

Parameter	EVVO 50000TL3P	EVVO 60000TL3P	EVVO 70000TL3P-HV		
Rated power	50000W	60000W	70000W		
Max. AC power	50000VA	60000VA	75000VA		
Rated AC voltage	3/N/PE,2	30/400Vac	3/N/PE,277/480Vac或 3/PE,480Vac		
Grid voltage range	310-480Vac	422-528Vac			
Grid frequency range	44~55Hz/54~66Hz(adjustable, must meet local grid requirements)				
Active power adjustable range	0-100%				
Max. output current	80A 9		90A		
THDI	<3%				
Power factor	1 (adjustable +/-0.8)				
Overvoltage category of output	III(II-52version)				



Annex 2

Pictures of the unit The full pictures refer to PHOTO DOCUMENT Project No.: 190627N026 Date: 20190723

No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 19 of 23





Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 20 of 23 Tel: +86 769 8998 2098 Fax: +86 769 8599 1080 Email: <u>customerservice.dg</u>@cn.bureauveritas.com TEST REPORT IEC61683 VER.0





Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 21 of 23 Tel: +86 769 8998 2098 Fax: +86 769 8599 1080 Email: <u>customerservice.dg</u>@cn.bureauveritas.com TEST REPORT IEC61683 VER.0





Annex 3 Test equipment list

Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch No. 34, Chenwulu Section, Guantai Rd., Houjie Town, Dongguan City, Guangdong 523942, China Page 22 of 23



Test location: Shenzhen Academy of Metrology & Quality Inspection Performed dates of test: 2018-12-20 to 2019-02-20

Equipment	Internal No.	Manufacturer	Туре	Serial No.	Last Calibration
Power Analyzer	SB11178	YOKOGAWA	WT3000	91P215776	2019/03/25
AC Source	SB14325	Chroma	61860	618603800236	Monitored by
DC Simulation	SB9540/02	Chroma	62000H		Power Analyzer
Power Supply					
RLC Load	SB9605	Qunling	ACLT-3830H		
PV inverter test	SB9540	Chroma		CH0240021207	
system					