






TEST REPORT IEC 61727 Photovoltaic (PV) systems – Characteristics of the utility interface	
Report Number	GZES201103204501
Date of issue	09 / 12 / 2020
Total number of pages	40
Name of Testing Laboratory preparing the Report	SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch
Applicant's name	EVOLVE ENERGY GROUP CO., LIMITED
Address	RM 702,7/F FU FAI COMM CTR 27 HILLIER ST SHEUNG WAN, HK
Test specification:	
Standard	IEC 61727:2004 (Second Edition)
Test procedure	Characteristic Examination
Non-standard test method	N/A
Test Report Form No.	IEC61727A
Test Report Form(s) Originator	TÜV SÜD Product Service GmbH
Master TRF	Dated 2014-11
<p>Copyright © 2014 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.</p> <p>This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.</p> <p>If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.</p> <p>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</p>	
General disclaimer:	
<p>The test results presented in this report relate only to the object tested.</p> <p>This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.</p>	



Test item description	Solar Grid-tied Inverter (Three Phase)
Trade Mark	
Manufacturer.....	EVOLVE ENERGY GROUP CO., LIMITED
Address	RM 702,7/F FU FAI COMM CTR 27 HILLIER ST SHEUNG WAN, HK
Model/Type reference	E- 75KTL, E- 80KTL, E- 100KTL, E- 110KTL E- 100KTL-HV, E- 125KTL-HV, E- 136KTL-HV
Ratings	See model list in Page 7 and Page 8.
	Serial Number: SQ1ES1A0L85001
	Firmware version: ARM V020010
	DSPS V020010
	DSPM V020010

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input type="checkbox"/>	CB Testing Laboratory:	
Testing location/ address.....:		
<input type="checkbox"/>	Associated CB Testing Laboratory:	
Testing location/ address.....:		
Tested by (name, function, signature).....:		
Approved by (name, function, signature)....:		
<input checked="" type="checkbox"/>	Testing procedure: TMP/CTF Stage 1:	Shenzhen BALUN Technology Co., Ltd.
Testing location/ address.....:		Room 104, 204, 205, Building 1, No. 6, Industrial South Road, Songshan Lake District, Dongguan, Guangdong, China
Tested by (name, function, signature).....:		Hugo Zhang (Project Engineer) 
Approved by (name, function, signature).....:		Roger Hu (Technical Reviewer) 
<input type="checkbox"/>	Testing procedure: WMT/CTF Stage 2:	
Testing location/ address.....:		
Tested by (name, function, signature).....:		
Witnessed by (name, function, signature) .::		
Approved by (name, function, signature)....:		
<input type="checkbox"/>	Testing procedure: SMT/CTF Stage 3 or 4:	
Testing location/ address.....:		
Tested by (name, function, signature).....:		
Witnessed by (name, function, signature) .::		
Approved by (name, function, signature)....:		
Supervised by (name, function, signature):		



List of Attachments (including a total number of pages in each attachment):		
50Hz/60Hz		
Attachment #	Description	Pages
Attachment I	Pictures of the EUT and Electrical Schemes	18 pages
Attachment II	Testing Information	5 pages
Attachment III	Graphs and Screenshots of Test Results	54 pages
Summary of testing:		
<p>Tests performed (name of test and test clause):</p> <p>The equipment has been tested according to the standard: IEC 61727:2004. Testing has been carried out at 50 Hz</p> <p>All applicable tests according to the above specified standard have been carried out.</p> <p>From the result of inspection and tests on the submitted sample, we conclude that it complies with the requirements of the standard.</p> <p>Remarks: All the test results are from the report below:</p> <ul style="list-style-type: none"> - IEC 61727:2004 (Second Edition) <p>Test Report No: GZES201203336801</p>	<p>Testing location:</p> <p>Shenzhen BALUN Technology Co., Ltd. Room 104, 204, 205, Building 1, No. 6, Industrial South Road, Songshan Lake District, Dongguan, Guangdong, China (All clauses)</p>	
Summary of compliance with National Differences:		
No National Differences are addressed to this test report		

Copy of marking plate(representative):

EVVO Solar Grid-tied Inverter	
Model No:	E-100KTL
Max.DC Input Voltage	1100V
Operating MPPT Voltage Range	180~1000V
Max. Input Current	10*26A
Max. PV Isc	10*40A
Rated Grid Voltage	3/N/PE, 380/400Vac
Max. Output Current	160A
Rated Grid Frequency	50/60Hz
Rated Output Power	100KW
Max. Output Power	110KVA
Power Factor	1(adjustable+/-0.8)
Ingress Protection	IP66
Operating Temperature Range	-30°C~+60°C
Protective Class	Class I
Overvoltage Category	AC III, DC II
Factory - Shenzhen China	
Manufacturer : EVOLVE ENERGY GROUP CO., LIMITED Address :RM 702, 7/F FU FAI COMM CTR 27 HILLIER ST SHEUNG WAN, HK Global Head Quarters 371 Sidco Industrial Estate Chennai 600098 India	
VDE0126-1-1, VDE-AR-N4105, G99, IEC61727 IEC62116, AS4777	

Note:

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation
3. Labels of other models are as the same with E- 100KTL's except the parameters of rating.

Test item particulars: Solar Grid-tied Inverter (Three Phase)	
Classification of installation and use: Fixed (permanent connection)	
Supply Connection: DC; PV	
.....: AC; Grid connection	
Possible test case verdicts:	
- test case does not apply to the test object..... : N/A	
- test object does meet the requirement..... : P (Pass)	
- test object does not meet the requirement..... : F (Fail)	
Testing : CTF Stage 1 procedure	
Date of receipt of test item : N/A	
Date (s) of performance of tests : From 20/07/2020 to 26/07/2020	
General remarks:	
<p>"(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report.</p> <p>This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.</p>	
<p>Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.</p>	
Manufacturer's Declaration per sub-clause 4.2.5 of IEC 61727:	
<p>The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided</p>	<p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable</p>
When differences exist; they shall be identified in the General product information section.	
<p>Name and address of factory (ies) : Dongguan SOFARSOLAR Co., Ltd. 1F - 6F, Building E, No. 1 JinQi Road, Bihu Industrial Park, Wulian Village, Fenggang Town, Dongguan, Guangdong, China.</p>	

General product information:

Product covered by this report is grid-connected PV inverter for indoor or outdoor installation. The connection to the DC input and AC output are through connectors.

The Solar inverter converts DC voltage into AC voltage.

The input and output are protected by varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit can operate in case of one error.

Equipment Under Testing:

- E- 100KTL

Variant models:

- E- 75KTL
- E- 80KTL
- E- 110KTL
- E- 100KTL-HV
- E- 125KTL-HV
- E- 136KTL-HV

Model	E- 75KTL	E- 80KTL	E- 100KTL	E- 110KTL	E- 100KTL -HV	E- 125KTL -HV	E- 136KTL -HV
DC Input							
Max. DC voltage	1100V						
Rated input voltage	625V	625V	625V	625V	725V	725V	785V
Start-up operating voltage	200V						
MPPT voltage range	180V~1000V						
Full power MPPT voltage range	500V-850V				550V-850V		
Max. input current	8*26A	8*26A	10*26A	10*26A	10*26A	10*26A	12*26A
Max. input short circuit current	8*40A	8*40A	10*40A	10*40A	10*40A	10*40A	12*40A
AC Output							
Rated power	75kW	80kW	100kW	110kW	100kW	125kW	136kW
Max. AC power	75kVA	88kVA	110kVA	121kVA	110kVA	137kVA	150kVA
Max. output current	113A	128A	160A	175A	128A	160A	160A

Nominal grid voltage	3/N/PE, 380V/400Vac	3/PE, 500Vac	3/PE, 540Vac
Nominal output frequency	50Hz/60Hz		
Output power factor	1 default (adjustable +/-0.8)		
Operating temperature range	-30°C ~60°C		
Ingress protection	IP66		
Protective class	Class I		

The variants models have been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology
- Same control algorithm.
- Output power within $1/\sqrt{10}$ and 2 times of the rated output power or the EUT or Modular inverters.
- Same Firmware Version

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict
4	UTILITY COMPATIBILITY		P
	The quality of power provided by the PV system for the on-site AC loads and for power delivered to the utility is governed by practices and standards on voltage, flicker, frequency, harmonics and power factor.		P
	Deviation from these standards represents out-of-bounds conditions and may require the PV system to sense the deviation and properly disconnect from the utility system.		P
4.1	Voltage, current and frequency		P
	The PV system AC voltage, current and frequency are compatible with the utility system.		P
4.2	Normal voltage operating range		P
	Utility-interconnected PV systems do not normally regulate voltage, they inject current into the utility. Therefore, the voltage operating range for PV inverters is selected as a protection function that responds to abnormal utility conditions, not as a voltage regulation function.		P
4.3	Flicker		P
	The operation of the PV system is not cause voltage flicker in excess of limits stated in the relevant sections of IEC 61000-3-3 for systems less than 16 A or IEC 61000-3-5 for systems with current of 16 A and above.	(see appended table)	P
4.4	DC injection		P
	The PV system is not inject DC current greater than 1 % of the rated inverter output current, into the utility AC interface under any operating condition.	(see appended table)	P
4.5	Normal frequency operating range		P
	The PV system operates in synchronism with the utility system, and within the frequency trip limits defined in 5.2.2.		P
4.6	Harmonics and waveform distortion		P
	Total harmonic current distortion is less than 5 % at rated inverter output. Each individual harmonic is limited to the percentages listed in Table 1.	(see appended table)	P
	Even harmonics in these ranges is less than 25 % of the lower odd harmonic limits listed.		P

IEC 61727																			
Clause	Requirement + Test	Result - Remark	Verdict																
	<p align="center">Table 1 – Current distortion limits</p> <table border="1"> <thead> <tr> <th>Odd harmonics</th> <th>Distortion limit</th> </tr> </thead> <tbody> <tr> <td>3rd through 9th</td> <td>Less than 4,0 %</td> </tr> <tr> <td>11th through 15th</td> <td>Less than 2,0 %</td> </tr> <tr> <td>17th through 21st</td> <td>Less than 1,5 %</td> </tr> <tr> <td>23rd through 33rd</td> <td>Less than 0,6 %</td> </tr> <tr> <th>Even harmonics</th> <th>Distortion limit</th> </tr> <tr> <td>2rd through 8th</td> <td>Less than 1,0 %</td> </tr> <tr> <td>10th through 32nd</td> <td>Less than 0,5 %</td> </tr> </tbody> </table>	Odd harmonics	Distortion limit	3 rd through 9 th	Less than 4,0 %	11 th through 15 th	Less than 2,0 %	17 th through 21 st	Less than 1,5 %	23 rd through 33 rd	Less than 0,6 %	Even harmonics	Distortion limit	2 rd through 8 th	Less than 1,0 %	10 th through 32 nd	Less than 0,5 %		P
Odd harmonics	Distortion limit																		
3 rd through 9 th	Less than 4,0 %																		
11 th through 15 th	Less than 2,0 %																		
17 th through 21 st	Less than 1,5 %																		
23 rd through 33 rd	Less than 0,6 %																		
Even harmonics	Distortion limit																		
2 rd through 8 th	Less than 1,0 %																		
10 th through 32 nd	Less than 0,5 %																		
4.7	The PV system has a lagging power factor greater than 0,9 when the output is greater than 50 % of the rated inverter output power.	(see appended table)	P																
5	PERSONNEL SAFETY AND EQUIPMENT PROTECTION		P																
	This Clause provides information and considerations for the safe and proper operation of the utility-connected PV systems.		P																
5.1	Loss of utility voltage		P																
	To prevent islanding, a utility connected PV system ceases to energize the utility system from a de-energized distribution line irrespective of connected loads or other generators within specified time limits.		P																
	A utility distribution line can become de-energized for several reasons. For example, a substation breaker opening due to fault conditions or the distribution line switched out during maintenance.		P																
5.2	Over/under voltage and frequency		P																
	The abnormal utility conditions of concern are voltage and frequency excursions above or below the values stated in this Clause, and the complete disconnection of the utility, presenting the potential for a distributed resource island.	(see appended table)	P																
5.2.1	Over/under voltage		P																
	When the interface voltage deviates outside the conditions specified in Table 2, the photovoltaic system ceases to energize the utility distribution system. This applies to any phase of a multiphase system.	(see appended table)	P																
	<p align="center">Table 2 – Response to abnormal voltages</p> <table border="1"> <thead> <tr> <th>Voltage (at point of utility connection)</th> <th>Maximum trip time*</th> </tr> </thead> <tbody> <tr> <td>$V < 0,5 \times V_{nominal}$</td> <td>0,1 s</td> </tr> <tr> <td>$50 \% \leq V < 85 \%$</td> <td>2,0 s</td> </tr> <tr> <td>$85 \% \leq V \leq 110 \%$</td> <td>Continuous operation</td> </tr> <tr> <td>$110 \% < V < 135 \%$</td> <td>2,0 s</td> </tr> <tr> <td>$135 \% \leq V$</td> <td>0,05 s</td> </tr> </tbody> </table> <p>* Trip time refers to the time between the abnormal condition occurring and the inverter ceasing to energize the utility line. The PV system control circuits shall actually remain connected to the utility to allow sensing of utility electrical conditions for use by the "reconnect" feature.</p>	Voltage (at point of utility connection)	Maximum trip time*	$V < 0,5 \times V_{nominal}$	0,1 s	$50 \% \leq V < 85 \%$	2,0 s	$85 \% \leq V \leq 110 \%$	Continuous operation	$110 \% < V < 135 \%$	2,0 s	$135 \% \leq V$	0,05 s		P				
Voltage (at point of utility connection)	Maximum trip time*																		
$V < 0,5 \times V_{nominal}$	0,1 s																		
$50 \% \leq V < 85 \%$	2,0 s																		
$85 \% \leq V \leq 110 \%$	Continuous operation																		
$110 \% < V < 135 \%$	2,0 s																		
$135 \% \leq V$	0,05 s																		
5.2.2	Over/under frequency		P																

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict
	When the utility frequency deviates outside the specified conditions the photovoltaic system ceases to energize the utility line. The unit does not have to cease to energize if the frequency returns to the normal utility continuous operation condition within the specified trip time.	(see appended table)	P
	When the utility frequency is outside the range of ± 1 Hz, the system ceases to energize the utility line within 0,2 s. The purpose of the allowed range and time delay is to allow continued operation for short-term disturbances and to avoid excessive nuisance tripping in weak-utility system conditions.		P
5.3	Islanding protection		P
	The PV system must cease to energize the utility line within 2 s of loss of utility.	Test according IEC 62116: 2014 Refer to Test Report No: GZES201103204502	P
5.4	Response to utility recovery		P
	Following an out-of-range utility condition that has caused the photovoltaic system to cease energizing, the photovoltaic system is not energize the utility line for 20 s to 5 min after the utility service voltage and frequency have recovered to within the specified ranges.	(see appended table)	P
5.5	Earthing		P
	The utility interface equipment is earthed/grounded in accordance with IEC 60364-7-712.		P
5.6	Short circuit protection		P
	The photovoltaic system has short-circuit protection in accordance with IEC 60364-7-712.		P
5.7	Isolation and switching		P
	A method of isolation and switching is provided in accordance with IEC 60364-7-712.		P

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.3	TABLE: Flicker				P
	Starting	Stopping	Running		
Limit	4%	4%	Pst = 1.0	Plt = 0.65	
33%Pn for 50Hz					
Test value (Phase A)	0.480	0.448	0.234	0.221	
Test value (Phase B)	0.469	0.413	0.233	0.227	
Test value (Phase C)	0.432	0.458	0.244	0.233	
66%Pn for 50Hz					
Test value (Phase A)	0.363	0.358	0.255	0.246	
Test value (Phase B)	0.524	0.517	0.258	0.247	
Test value (Phase C)	0.440	0.352	0.253	0.230	
100%Pn for 50Hz					
Test value (Phase A)	0.407	0.379	0.323	0.296	
Test value (Phase B)	0.580	0.544	0.357	0.320	
Test value (Phase C)	0.351	0.303	0.385	0.339	
33%Pn for 60Hz					
Test value (Phase A)	0.359	0.365	0.276	0.274	
Test value (Phase B)	0.450	0.457	0.278	0.277	
Test value (Phase C)	0.495	0.417	0.282	0.281	
66%Pn for 60Hz					
Test value (Phase A)	0.365	0.355	0.290	0.278	
Test value (Phase B)	0.440	0.464	0.290	0.280	
Test value (Phase C)	0.355	0.375	0.281	0.272	
100%Pn for 60Hz					
Test value (Phase A)	0.408	0.423	0.297	0.279	
Test value (Phase B)	0.499	0.462	0.304	0.273	
Test value (Phase C)	0.350	0.367	0.294	0.278	

Supplementary information:
 The measurements of voltage fluctuations have been measured at 33 %, 66% and 100 % of the nominal power value of the inverter.
 As it can be seen in screenshots in Attachment III, this test has two steps and 10min for each step:

- 1.Starting operation
- 2.Stopping operation

The values took of Pst and Plt are the most unfavorable of the two steps.
 As it can be seen in the screenshots in Attachment III. The values took of Pst and Plt are the most unfavorable of the twelve steps and 10min for each step for running operation

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.4	TABLE: Direct current injection								P
50Hz									
Rated output current (A)	Ratio of rated output power (VA)	Measured DC output current between terminals (A)						Isolated transformer ? (Yes/No)	Limit (A)
		L1-L2	L1-L3	L2-L3	L1-N	L2-N	L3-N		
144.9	33%	--	--	--	0.107	0.388	0.096	No	1.449
144.9	66%	--	--	--	0.090	0.336	0.099	No	1.449
144.9	100%	--	--	--	0.206	0.103	0.142	No	1.449
60Hz									
Rated output current (A)	Ratio of rated output power (VA)	Measured DC output current between terminals (A)						Isolated transformer ? (Yes/No)	Limit (A)
		L1-L2	L1-L3	L2-L3	L1-N	L2-N	L3-N		
151.5	33%	--	--	--	0.152	0.273	0.181	No	1.515
151.5	66%	--	--	--	0.164	0.177	0.220	No	1.515
151.5	100%	--	--	--	0.178	0.111	0.152	No	1.515
Supplementary information: N/A									

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(a)	Table: harmonics and waveform distortion (at 33%Pn Phase A, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.205	1.000	03	0.201	4.000	
04	0.177	1.000	05	0.511	4.000	
06	0.429	1.000	07	0.278	4.000	
08	0.177	1.000	09	0.277	4.000	
10	0.165	0.500	11	0.404	2.000	
12	0.255	0.500	13	0.251	2.000	
14	0.143	0.500	15	0.224	2.000	
16	0.150	0.500	17	0.244	1.500	
18	0.227	0.500	19	0.226	1.500	
20	0.134	0.500	21	0.192	1.500	
22	0.125	0.500	23	0.187	0.600	
24	0.141	0.500	25	0.214	0.600	
26	0.157	0.500	27	0.142	0.600	
28	0.105	0.500	29	0.179	0.600	
30	0.134	0.500	31	0.238	0.600	
32	0.189	0.500	33	0.122	0.600	
THD	1.305	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(b)	Table: harmonics and waveform distortion (at 33%Pn Phase B, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.192	1.000	03	0.195	4.000	
04	0.168	1.000	05	0.315	4.000	
06	0.455	1.000	07	0.325	4.000	
08	0.155	1.000	09	0.230	4.000	
10	0.154	0.500	11	0.348	2.000	
12	0.260	0.500	13	0.311	2.000	
14	0.142	0.500	15	0.222	2.000	
16	0.162	0.500	17	0.243	1.500	
18	0.311	0.500	19	0.265	1.500	
20	0.133	0.500	21	0.235	1.500	
22	0.126	0.500	23	0.224	0.600	
24	0.177	0.500	25	0.264	0.600	
26	0.159	0.500	27	0.153	0.600	
28	0.126	0.500	29	0.212	0.600	
30	0.143	0.500	31	0.301	0.600	
32	0.227	0.500	33	0.139	0.600	
THD	1.324	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(c)	Table: harmonics and waveform distortion (at 33%Pn Phase C, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.197	1.000	03	0.201	4.000	
04	0.164	1.000	05	0.510	4.000	
06	0.327	1.000	07	0.358	4.000	
08	0.167	1.000	09	0.274	4.000	
10	0.159	0.500	11	0.336	2.000	
12	0.216	0.500	13	0.272	2.000	
14	0.156	0.500	15	0.292	2.000	
16	0.152	0.500	17	0.207	1.500	
18	0.258	0.500	19	0.240	1.500	
20	0.149	0.500	21	0.221	1.500	
22	0.136	0.500	23	0.192	0.600	
24	0.159	0.500	25	0.213	0.600	
26	0.157	0.500	27	0.157	0.600	
28	0.129	0.500	29	0.221	0.600	
30	0.138	0.500	31	0.281	0.600	
32	0.242	0.500	33	0.141	0.600	
THD	1.323	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(d)	Table: harmonics and waveform distortion (at 66%Pn Phase A, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.098	1.000	03	0.156	4.000	
04	0.104	1.000	05	0.163	4.000	
06	0.232	1.000	07	0.161	4.000	
08	0.095	1.000	09	0.214	4.000	
10	0.098	0.500	11	0.115	2.000	
12	0.151	0.500	13	0.124	2.000	
14	0.091	0.500	15	0.131	2.000	
16	0.095	0.500	17	0.085	1.500	
18	0.130	0.500	19	0.113	1.500	
20	0.078	0.500	21	0.105	1.500	
22	0.070	0.500	23	0.074	0.600	
24	0.083	0.500	25	0.105	0.600	
26	0.075	0.500	27	0.087	0.600	
28	0.069	0.500	29	0.093	0.600	
30	0.078	0.500	31	0.114	0.600	
32	0.088	0.500	33	0.072	0.600	
THD	0.665	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(e)	Table: harmonics and waveform distortion (at 66%Pn Phase B, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.114	1.000	03	0.143	4.000	
04	0.089	1.000	05	0.114	4.000	
06	0.253	1.000	07	0.125	4.000	
08	0.085	1.000	09	0.162	4.000	
10	0.086	0.500	11	0.094	2.000	
12	0.146	0.500	13	0.131	2.000	
14	0.088	0.500	15	0.125	2.000	
16	0.085	0.500	17	0.079	1.500	
18	0.174	0.500	19	0.133	1.500	
20	0.078	0.500	21	0.129	1.500	
22	0.070	0.500	23	0.081	0.600	
24	0.102	0.500	25	0.133	0.600	
26	0.079	0.500	27	0.086	0.600	
28	0.070	0.500	29	0.088	0.600	
30	0.084	0.500	31	0.146	0.600	
32	0.110	0.500	33	0.076	0.600	
THD	0.664	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(f)	Table: harmonics and waveform distortion (at 66%Pn Phase C, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.113	1.000	03	0.126	4.000	
04	0.098	1.000	05	0.189	4.000	
06	0.203	1.000	07	0.145	4.000	
08	0.096	1.000	09	0.186	4.000	
10	0.094	0.500	11	0.118	2.000	
12	0.125	0.500	13	0.127	2.000	
14	0.092	0.500	15	0.158	2.000	
16	0.094	0.500	17	0.091	1.500	
18	0.135	0.500	19	0.112	1.500	
20	0.085	0.500	21	0.121	1.500	
22	0.081	0.500	23	0.082	0.600	
24	0.091	0.500	25	0.105	0.600	
26	0.086	0.500	27	0.088	0.600	
28	0.078	0.500	29	0.101	0.600	
30	0.086	0.500	31	0.119	0.600	
32	0.120	0.500	33	0.082	0.600	
THD	0.667	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(g)	Table: harmonics and waveform distortion (at 100%Pn Phase A, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.167	1.000	03	0.076	4.000	
04	0.125	1.000	05	0.126	4.000	
06	0.161	1.000	07	0.151	4.000	
08	0.092	1.000	09	0.093	4.000	
10	0.076	0.500	11	0.154	2.000	
12	0.102	0.500	13	0.148	2.000	
14	0.082	0.500	15	0.082	2.000	
16	0.070	0.500	17	0.114	1.500	
18	0.113	0.500	19	0.128	1.500	
20	0.074	0.500	21	0.076	1.500	
22	0.059	0.500	23	0.131	0.600	
24	0.073	0.500	25	0.117	0.600	
26	0.063	0.500	27	0.066	0.600	
28	0.052	0.500	29	0.091	0.600	
30	0.062	0.500	31	0.101	0.600	
32	0.061	0.500	33	0.061	0.600	
THD	0.587	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(h)	Table: harmonics and waveform distortion (at 100%Pn Phase B, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.181	1.000	03	0.169	4.000	
04	0.088	1.000	05	0.109	4.000	
06	0.214	1.000	07	0.099	4.000	
08	0.086	1.000	09	0.096	4.000	
10	0.067	0.500	11	0.126	2.000	
12	0.107	0.500	13	0.130	2.000	
14	0.076	0.500	15	0.095	2.000	
16	0.070	0.500	17	0.106	1.500	
18	0.146	0.500	19	0.132	1.500	
20	0.069	0.500	21	0.091	1.500	
22	0.062	0.500	23	0.123	0.600	
24	0.078	0.500	25	0.133	0.600	
26	0.069	0.500	27	0.077	0.600	
28	0.058	0.500	29	0.085	0.600	
30	0.065	0.500	31	0.106	0.600	
32	0.070	0.500	33	0.066	0.600	
THD	0.611	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(i)	Table: harmonics and waveform distortion (at 100%Pn Phase C, 50Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.103	1.000	03	0.155	4.000	
04	0.126	1.000	05	0.156	4.000	
06	0.304	1.000	07	0.140	4.000	
08	0.092	1.000	09	0.115	4.000	
10	0.084	0.500	11	0.135	2.000	
12	0.151	0.500	13	0.147	2.000	
14	0.088	0.500	15	0.105	2.000	
16	0.081	0.500	17	0.108	1.500	
18	0.207	0.500	19	0.137	1.500	
20	0.079	0.500	21	0.100	1.500	
22	0.070	0.500	23	0.124	0.600	
24	0.090	0.500	25	0.127	0.600	
26	0.074	0.500	27	0.078	0.600	
28	0.061	0.500	29	0.086	0.600	
30	0.070	0.500	31	0.105	0.600	
32	0.076	0.500	33	0.072	0.600	
THD	0.698	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(a)	Table: harmonics and waveform distortion (at 33%Pn Phase A, 60Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.173	1.000	03	0.255	4.000	
04	0.631	1.000	05	0.212	4.000	
06	0.329	1.000	07	0.209	4.000	
08	0.172	1.000	09	0.299	4.000	
10	0.307	0.500	11	0.154	2.000	
12	0.197	0.500	13	0.176	2.000	
14	0.279	0.500	15	0.140	2.000	
16	0.154	0.500	17	0.120	1.500	
18	0.145	0.500	19	0.170	1.500	
20	0.123	0.500	21	0.112	1.500	
22	0.111	0.500	23	0.121	0.600	
24	0.174	0.500	25	0.102	0.600	
26	0.100	0.500	27	0.094	0.600	
28	0.131	0.500	29	0.114	0.600	
30	0.126	0.500	31	0.086	0.600	
32	0.084	0.500	33	0.089	0.600	
THD	1.169	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(b)	Table: harmonics and waveform distortion (at 33%Pn Phase B, 60Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.271	1.000	03	0.191	4.000	
04	0.220	1.000	05	0.520	4.000	
06	0.201	1.000	07	0.265	4.000	
08	0.158	1.000	09	0.176	4.000	
10	0.292	0.500	11	0.275	2.000	
12	0.141	0.500	13	0.186	2.000	
14	0.175	0.500	15	0.345	2.000	
16	0.136	0.500	17	0.148	1.500	
18	0.111	0.500	19	0.173	1.500	
20	0.188	0.500	21	0.116	1.500	
22	0.100	0.500	23	0.110	0.600	
24	0.131	0.500	25	0.175	0.600	
26	0.096	0.500	27	0.083	0.600	
28	0.082	0.500	29	0.132	0.600	
30	0.111	0.500	31	0.117	0.600	
32	0.077	0.500	33	0.077	0.600	
THD	1.113	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(c)	Table: harmonics and waveform distortion (at 33%Pn Phase C, 60Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.252	1.000	03	0.200	4.000	
04	0.223	1.000	05	0.571	4.000	
06	0.184	1.000	07	0.391	4.000	
08	0.161	1.000	09	0.170	4.000	
10	0.267	0.500	11	0.287	2.000	
12	0.138	0.500	13	0.228	2.000	
14	0.167	0.500	15	0.276	2.000	
16	0.137	0.500	17	0.149	1.500	
18	0.113	0.500	19	0.168	1.500	
20	0.172	0.500	21	0.124	1.500	
22	0.104	0.500	23	0.121	0.600	
24	0.122	0.500	25	0.168	0.600	
26	0.102	0.500	27	0.101	0.600	
28	0.090	0.500	29	0.152	0.600	
30	0.113	0.500	31	0.121	0.600	
32	0.093	0.500	33	0.080	0.600	
THD	1.157	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(d)	Table: harmonics and waveform distortion (at 66%Pn Phase A, 60Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.318	1.000	03	0.125	4.000	
04	0.143	1.000	05	0.316	4.000	
06	0.110	1.000	07	0.180	4.000	
08	0.103	1.000	09	0.093	4.000	
10	0.149	0.500	11	0.221	2.000	
12	0.083	0.500	13	0.202	2.000	
14	0.085	0.500	15	0.129	2.000	
16	0.073	0.500	17	0.168	1.500	
18	0.066	0.500	19	0.150	1.500	
20	0.089	0.500	21	0.063	1.500	
22	0.061	0.500	23	0.146	0.600	
24	0.066	0.500	25	0.120	0.600	
26	0.056	0.500	27	0.053	0.600	
28	0.053	0.500	29	0.084	0.600	
30	0.061	0.500	31	0.083	0.600	
32	0.050	0.500	33	0.048	0.600	
THD	0.768	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(e)	Table: harmonics and waveform distortion (at 66%Pn Phase B, 60Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.202	1.000	03	0.164	4.000	
04	0.105	1.000	05	0.285	4.000	
06	0.089	1.000	07	0.102	4.000	
08	0.080	1.000	09	0.094	4.000	
10	0.157	0.500	11	0.172	2.000	
12	0.070	0.500	13	0.152	2.000	
14	0.087	0.500	15	0.176	2.000	
16	0.070	0.500	17	0.146	1.500	
18	0.060	0.500	19	0.140	1.500	
20	0.095	0.500	21	0.061	1.500	
22	0.053	0.500	23	0.144	0.600	
24	0.063	0.500	25	0.123	0.600	
26	0.049	0.500	27	0.047	0.600	
28	0.043	0.500	29	0.087	0.600	
30	0.055	0.500	31	0.081	0.600	
32	0.041	0.500	33	0.041	0.600	
THD	0.668	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(f)	Table: harmonics and waveform distortion (at 66%Pn Phase C, 60Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.244	1.000	03	0.123	4.000	
04	0.113	1.000	05	0.282	4.000	
06	0.095	1.000	07	0.167	4.000	
08	0.085	1.000	09	0.093	4.000	
10	0.145	0.500	11	0.193	2.000	
12	0.074	0.500	13	0.196	2.000	
14	0.080	0.500	15	0.150	2.000	
16	0.070	0.500	17	0.149	1.500	
18	0.062	0.500	19	0.159	1.500	
20	0.084	0.500	21	0.067	1.500	
22	0.060	0.500	23	0.134	0.600	
24	0.064	0.500	25	0.127	0.600	
26	0.054	0.500	27	0.053	0.600	
28	0.049	0.500	29	0.083	0.600	
30	0.056	0.500	31	0.082	0.600	
32	0.049	0.500	33	0.043	0.600	
THD	0.700	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(g)	Table: harmonics and waveform distortion (at 100%Pn Phase A, 60Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.157	1.000	03	0.077	4.000	
04	0.119	1.000	05	0.151	4.000	
06	0.083	1.000	07	0.125	4.000	
08	0.071	1.000	09	0.055	4.000	
10	0.075	0.500	11	0.146	2.000	
12	0.054	0.500	13	0.146	2.000	
14	0.053	0.500	15	0.088	2.000	
16	0.045	0.500	17	0.106	1.500	
18	0.044	0.500	19	0.100	1.500	
20	0.048	0.500	21	0.043	1.500	
22	0.039	0.500	23	0.116	0.600	
24	0.039	0.500	25	0.096	0.600	
26	0.037	0.500	27	0.035	0.600	
28	0.032	0.500	29	0.069	0.600	
30	0.032	0.500	31	0.059	0.600	
32	0.031	0.500	33	0.029	0.600	
THD	0.479	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(h)	Table: harmonics and waveform distortion (at 100%Pn Phase B, 60Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.152	1.000	03	0.110	4.000	
04	0.099	1.000	05	0.188	4.000	
06	0.077	1.000	07	0.068	4.000	
08	0.062	1.000	09	0.059	4.000	
10	0.088	0.500	11	0.125	2.000	
12	0.051	0.500	13	0.105	2.000	
14	0.062	0.500	15	0.117	2.000	
16	0.046	0.500	17	0.085	1.500	
18	0.041	0.500	19	0.086	1.500	
20	0.053	0.500	21	0.040	1.500	
22	0.038	0.500	23	0.112	0.600	
24	0.043	0.500	25	0.099	0.600	
26	0.036	0.500	27	0.033	0.600	
28	0.033	0.500	29	0.064	0.600	
30	0.034	0.500	31	0.060	0.600	
32	0.030	0.500	33	0.029	0.600	
THD	0.464	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.6(i)	Table: harmonics and waveform distortion (at 100%Pn Phase C, 60Hz)					P
Harmonic	% of fundamental	Limits (% of fundamental)	Harmonic	% of fundamental	Limits (% of fundamental)	
02	0.063	1.000	03	0.098	4.000	
04	0.081	1.000	05	0.238	4.000	
06	0.070	1.000	07	0.109	4.000	
08	0.060	1.000	09	0.061	4.000	
10	0.106	0.500	11	0.127	2.000	
12	0.051	0.500	13	0.141	2.000	
14	0.054	0.500	15	0.160	2.000	
16	0.046	0.500	17	0.095	1.500	
18	0.042	0.500	19	0.104	1.500	
20	0.059	0.500	21	0.046	1.500	
22	0.040	0.500	23	0.104	0.600	
24	0.041	0.500	25	0.107	0.600	
26	0.036	0.500	27	0.039	0.600	
28	0.033	0.500	29	0.061	0.600	
30	0.035	0.500	31	0.065	0.600	
32	0.033	0.500	33	0.028	0.600	
THD	0.499	5.000	--	--	--	
Supplementary information:						

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

4.7	TABLE: Power factor		P
-----	----------------------------	--	----------

50Hz									
No	Input			Output				Rated output (V.A)	
	Voltage (V d.c.)	Current (A d.c.)	Power (KW)	Voltage (V a.c.)	Current (A a.c.)	Power (KW)	Power factor		
1	741.7	28.6	21.1	230.2	30.1	20.6	a	0.992	(20±5)%
							b	0.993	
							c	N/A	
3	745.1	41.2	30.6	230.2	43.5	29.9	a	0.995	(30±5)%
							b	0.996	
							c	N/A	
3	745.9	55.2	41.2	230.2	58.4	40.2	a	0.997	(40±5)%
							b	0.998	
							c	N/A	
4	747.5	69.3	51.7	230.3	73.3	50.5	a	0.998	(50±5)%
							b	0.999	
							c	N/A	
5	746.3	83.5	62.3	230.3	88.1	60.8	a	0.998	(60±5)%
							b	0.999	
							c	N/A	
6	746.9	115.3	87.4	230.3	88.2	70.0	a	0.998	(70±5)%
							b	0.999	
							c	N/A	
7	746.3	110.2	82.2	230.3	116.1	80.1	a	0.998	(80±5)%
							b	0.999	
							c	N/A	
8	746.9	124.2	92.8	230.4	130.8	90.3	a	0.998	(90±5)%
							b	0.999	
							c	N/A	
9	786.9	130.6	102.7	230.4	144.7	99.8	a	0.999	(100±5)%
							b	0.999	
							c	N/A	

Supplementary information:

Power factor with “+” indicating leading and “-“ indicating lagging

Each power stage has been maintained during 120 seconds for measurements with a sampling rate of 0.2 s.

Values offered correspond with the 120s average measured with each corresponding stage.

Except for power factor measurements, where:

The value a) indicates the average of measured absolute PF values during each 120s stage of measurement.

The value b) indicates the maximum leading PF value measured during each 120s stage of measurement.

The value c) indicates the maximum lagging PF value measured during each 120s stage of measurement.

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

60Hz									
No	Input			Output				Rated output (V.A)	
	Voltage (V d.c.)	Current (A d.c.)	Power (KW)	Voltage (V a.c.)	Current (A a.c.)	Power (KW)	Power factor		
1	742.4	28.6	21.1	220.2	31.4	20.6	a	0.991	(20±5)%
							b	0.992	
							c	N/A	
3	744.4	41.2	30.6	220.2	45.4	29.9	a	0.996	(30±5)%
							b	0.996	
							c	N/A	
3	746.7	55.2	41.2	220.3	61.0	40.2	a	0.997	(40±5)%
							b	0.997	
							c	N/A	
4	746.4	69.3	51.7	220.3	76.4	50.4	a	0.999	(50±5)%
							b	0.999	
							c	N/A	
5	746.5	83.4	62.2	220.3	91.9	60.7	a	0.999	(60±5)%
							b	0.999	
							c	N/A	
6	745.5	116.1	87.9	220.3	92.0	70.8	a	0.999	(70±5)%
							b	0.999	
							c	N/A	
7	745.2	111.8	83.3	220.4	122.6	81.0	a	0.999	(80±5)%
							b	0.999	
							c	N/A	
8	745.1	124.5	92.7	220.4	136.5	90.1	a	0.999	(90±5)%
							b	0.999	
							c	N/A	
9	787.3	130.5	102.7	220.4	150.9	99.7	a	0.999	(100±5)%
							b	0.999	
							c	N/A	

Supplementary information:

Power factor with “+” indicating leading and “-“ indicating lagging

Each power stage has been maintained during 120 seconds for measurements with a sampling rate of 0.2 s.

Values offered correspond with the 120s average measured with each corresponding stage.

Except for power factor measurements, where:

The value a) indicates the average of measured absolute PF values during each 120s stage of measurement.

The value b) indicates the maximum leading PF value measured during each 120s stage of measurement.

The value c) indicates the maximum lagging PF value measured during each 120s stage of measurement.

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

5.2.1 & 5.4		TABLE: Under-and over-voltage trip settings and reconnection test						P
(1) Under voltage disconnection procedure								
Rated output voltage (V)	Output power (VA)	Required min. voltage (V)	Value of PCE trip settings (V)	Ratio of decreased (V / s)	Interval time (ms)	Measured tripped voltage (V)	Measured disconnection time (ms)	
50 % $V_n \leq V < 85 \% V_n$ Phase ABC								
230	100000	195.5	195.5	--	2000	194.7	1614	
230	100000	155	155	--	2000	154.8	1610	
230	100000	117	117	--	2000	115.7	1620	
$V < 50\%V_n$ Phase ABC								
230	100000	114	114	--	100	113.5	89	
(2) Under voltage reconnection procedure								
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)		Reconnection time (s)			
--			198.1		112.4			
(3) Over voltage disconnection procedure								
Rated output voltage (V)	Output power (VA)	Required max. voltage (V)	Value of PCE trip settings (V)	Ratio of increased (V / s)	Interval time (ms)	Measured tripped voltage (V)	Measured disconnection time (ms)	
110 % $V_n < V < 135 \% V_n$ Phase ABC								
230	100000	253	255	--	2000	254.6	1326	
230	100000	282	282	--	2000	281.5	1348	
230	100000	309	309	--	2000	307.4	1641	
135 % $V_n \leq V$ Phase ABC								
230	100000	312	312	--	50	310.4	42	
(4) Over voltage reconnection procedure								
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)		Reconnection time (s)			
--			249.6		129.4			
Supplementary information: N/A								

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

(1) Under voltage disconnection procedure							
Rated output voltage (V)	Output power (VA)	Required min. voltage (V)	Value of PCE trip settings (V)	Ratio of decreased (V / s)	Interval time (ms)	Measured tripped voltage (V)	Measured disconnection time (ms)
50 % Vn ≤ V < 85 % Vn Phase ABC							
220	100000	186	186	--	2000	184.8	1609
220	100000	149	149	--	2000	147.7	1973
220	100000	111	111	--	2000	109.7	1607
V < 50%Vn Phase ABC							
220	100000	109	109	--	100	107.6	79
(2) Under voltage reconnection procedure							
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)		Reconnection time (s)		
--			189.1		138.2		
(3) Over voltage disconnection procedure							
Rated output voltage (V)	Output power (VA)	Required max. voltage (V)	Value of PCE trip settings (V)	Ratio of increased (V / s)	Interval time (ms)	Measured tripped voltage (V)	Measured disconnection time (ms)
110 % Vn < V < 135 % Vn Phase ABC							
220	100000	241	241	--	2000	241.8	1626
220	100000	270	270	--	2000	268.5	1946
220	100000	296	296	--	2000	294.5	1612
135 % Vn ≤ V Phase ABC							
220	100000	298	298	--	50	296.4	24
(4) Over voltage reconnection procedure							
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)		Reconnection time (s)		
--			240.0		149.6		
Supplementary information: N/A							

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

5.2.2 & 5.4		TABLE: Over/under frequency trip settings and reconnection test						Pass
(1) Under frequency disconnection procedure								
Rated output frequency (Hz)	Output power (VA)	Required min. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of decreased (Hz / s)	Interval time (ms)	Measured tripped frequency (Hz)	Measured disconnection time (ms)	
50	100000	49	49	--	200	49.0	163	
(2) Under frequency reconnection procedure								
Ratio of voltage rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)			
--			49.1		117.2			
(3) Over frequency disconnection procedure								
Rated output frequency (Hz)	Output power (VA)	Required max. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of increased (Hz / s)	Interval time (ms)	Measured tripped frequency (Hz)	Measured disconnection time (ms)	
50	100000	51	51	--	200	51.0	188	
(4) Over frequency reconnection procedure								
Ratio of voltage rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)			
--			50.9		76			
(1) Under frequency disconnection procedure								
Rated output frequency (Hz)	Output power (VA)	Required min. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of decreased (Hz / s)	Interval time (ms)	Measured tripped frequency (Hz)	Measured disconnection time (ms)	
60	100000	59	59	--	200	58.9	90	
(2) Under frequency reconnection procedure								
Ratio of voltage rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)			
--			59.1		141			
(3) Over frequency disconnection procedure								
Rated output frequency (Hz)	Output power (VA)	Required max. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of increased (Hz / s)	Interval time (ms)	Measured tripped frequency (Hz)	Measured disconnection time (ms)	
60	100000	61	61	--	200	61.1	57	
(4) Over frequency reconnection procedure								
Ratio of voltage rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)			
--			60.9		139			
Supplementary information: N/A								

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

5.3	Table: tested condition and run-on time								P
50Hz									
No.	P _{EUT} (% of EUT rating)	Reactive load (% of normal)	P _{AC}	Q _{AC}	Run-on time(ms)	P _{EUT} (KW)	Actual Q _f	V _{DC} (d.c.V)	Which load is selected to be adjusted (R or L)
Test condition A									
1	100	100	0	0	488	102.1	1.00	796.1	--
2	100	100	-5	-5	367	101.8	1.02	796.2	R/L
3	100	100	-5	0	437	101.5	1.04	797.1	R
4	100	100	-5	+5	353	101.4	1.05	797.5	R/L
5	100	100	0	-5	431	101.7	0.97	797.2	L
6	100	100	0	+5	395	101.0	1.02	797.4	L
7	100	100	+5	-5	381	102.0	0.95	798.5	R/L
8	100	100	+5	0	419	101.9	0.95	797.3	R
9	100	100	+5	+5	404	101.6	0.97	798.2	R/L
10	100	100	-10	+10	--	--	--	--	R/L
11	100	100	-5	+10	--	--	--	--	R/L
12	100	100	0	+10	--	--	--	--	L
13	100	100	+10	+10	--	--	--	--	R/L
14	100	100	+10	+5	--	--	--	--	R/L
15	100	100	+10	0	--	--	--	--	R
16	100	100	+10	-5	--	--	--	--	R/L
17	100	100	+10	-10	--	--	--	--	R/L
18	100	100	+5	-10	--	--	--	--	R/L
19	100	100	+5	10	--	--	--	--	R/L
20	100	100	0	-10	--	--	--	--	L
21	100	100	-5	-10	--	--	--	--	R/L
22	100	100	-10	-10	--	--	--	--	R/L
23	100	100	-10	-5	--	--	--	--	R/L
24	100	100	-10	0	--	--	--	--	R/L

IEC 61727									
Clause	Requirement + Test					Result - Remark			Verdict
25	100	100	-10	+5	--	--	--	--	R/L
Test condition B									
10	66	66	0	0	460	65.2	1.00	588.8	--
11	66	66	0	-5	105	65.4	0.98	588.3	L
12	66	66	0	-4	278	65.8	0.98	588.5	L
13	66	66	0	-3	397	65.6	0.99	588.7	L
14	66	66	0	-2	471	65.0	0.99	589.1	L
15	66	66	0	-1	460	65.4	1.00	589.5	L
16	66	66	0	1	460	65.3	1.00	588.6	L
17	66	66	0	2	468	65.7	0.99	589.4	L
18	66	66	0	3	142	65.5	0.98	589.2	L
19	66	66	0	4	318	65.4	0.98	589.8	L
20	66	66	0	5	70	65.6	0.98	589.3	L
21	66	66	0	6	--	--	--	--	L
Test condition C									
22	33	33	0	0	390	32.7	1.00	335.4	--
23	33	33	0	-5	197	32.9	0.98	335.2	L
24	33	33	0	-4	259	33.1	0.98	335.7	L
25	33	33	0	-3	487	33.2	0.99	335.1	L
26	33	33	0	-2	394	32.8	0.99	335.0	L
27	33	33	0	-1	387	32.5	1.00	334.9	L
28	33	33	0	1	493	32.9	1.01	335.5	L
29	33	33	0	2	356	33.0	1.01	335.8	L
30	33	33	0	3	466	33.4	1.02	334.8	L
31	33	33	0	4	488	33.1	1.02	335.5	L
32	33	33	0	5	409	32.8	1.03	335.2	L
33	33	33	0	6	--	--	--	--	L

IEC 61727			
Clause	Requirement + Test	Result - Remark	Verdict

60Hz									
No.	P _{EUT} (% of EUT rating)	Reactive load (% of normal)	P _{AC}	Q _{AC}	Run-on time(ms)	P _{EUT} (KW)	Actual Q _f	V _{DC} (d.c.V)	Which load is selected to be adjusted (R or L)
Test condition A									
1	100	100	0	0	417	101.1	1.00	796.5	--
2	100	100	-5	-5	325	101.0	1.03	796.8	R/L
3	100	100	-5	0	363	100.9	1.05	797.0	R
4	100	100	-5	+5	343	100.5	1.05	797.3	R/L
5	100	100	0	-5	289	101.0	0.98	796.7	L
6	100	100	0	+5	393	101.4	1.03	797.1	L
7	100	100	+5	-5	330	101.5	0.95	797.2	R/L
8	100	100	+5	0	352	100.6	0.95	797.4	R
9	100	100	+5	+5	324	101.7	0.98	798.1	R/L
10	100	100	-10	+10	--	--	--	--	R/L
11	100	100	-5	+10	--	--	--	--	R/L
12	100	100	0	+10	--	--	--	--	L
13	100	100	+10	+10	--	--	--	--	R/L
14	100	100	+10	+5	--	--	--	--	R/L
15	100	100	+10	0	--	--	--	--	R
16	100	100	+10	-5	--	--	--	--	R/L
17	100	100	+10	-10	--	--	--	--	R/L
18	100	100	+5	-10	--	--	--	--	R/L
19	100	100	+5	10	--	--	--	--	R/L
20	100	100	0	-10	--	--	--	--	L
21	100	100	-5	-10	--	--	--	--	R/L
22	100	100	-10	-10	--	--	--	--	R/L
23	100	100	-10	-5	--	--	--	--	R/L
24	100	100	-10	0	--	--	--	--	R/L
25	100	100	-10	+5	--	--	--	--	R/L
Test condition B									

IEC 61727									
Clause	Requirement + Test					Result - Remark			Verdict
10	66	66	0	0	308	66.2	1.00	588.4	--
11	66	66	0	-5	309	66.4	0.97	588.8	L
12	66	66	0	-4	365	66.3	0.98	589.1	L
13	66	66	0	-3	333	65.8	0.99	588.6	L
14	66	66	0	-2	332	65.7	0.99	589.3	L
15	66	66	0	-1	284	65.9	1.00	589.1	L
16	66	66	0	1	374	66.3	1.01	588.5	L
17	66	66	0	2	349	65.9	1.01	589.7	L
18	66	66	0	3	390	66.3	1.02	589.0	L
19	66	66	0	4	396	66.4	1.02	589.4	L
20	66	66	0	5	329	65.8	1.02	589.9	L
21	66	66	0	6	--	--	--	--	L
Test condition C									
22	33	33	0	0	416	33.2	1.00	334.8	--
23	33	33	0	-5	327	33.2	0.97	334.6	L
24	33	33	0	-4	345	33.2	0.98	335.2	L
25	33	33	0	-3	407	33.2	0.99	335.4	L
26	33	33	0	-2	296	33.2	0.99	334.9	L
27	33	33	0	-1	390	33.2	1.00	334.7	L
28	33	33	0	1	351	33.2	1.00	335.3	L
29	33	33	0	2	354	33.2	1.01	335.5	L
30	33	33	0	3	428	33.2	1.02	334.6	L
31	33	33	0	4	324	33.2	1.02	335.3	L
32	33	33	0	5	163	33.2	1.03	335.1	L
33	33	33	0	6	--	--	--	--	L
<p>Remark:</p> <p>For test condition A: If any of the recorded run-on times are longer than the one recorded for the rated balance condition, then the non-shaded parameter combinations also require testing.</p> <p>For test condition B and C: If run-on times are still increasing at the 95 % or 105 % points, additional 1 % increments is taken until run-on times begin decreasing.</p> <p>The compliances with these requirements are stated in the following test report: IEC 62116: test report n° GZES201103204502</p>									

--- End of test report---

Attachment I

(Pictures of the EUT and Electrical Schemes)

1 PICTURES

Front view



Back view (E-75KTL, E-80KTL)



Back view
(E- 100KTL, E- 100KTL-HV, E-110KTL, E- 125KTL-HV)



Back view (E- 136KTL-HV)



IEC 61727:2004 (50Hz/60Hz)

DC Connection interface (E-75KTL, E-80KTL)



DC Connection interface
(E-100KTL, E-100KTL-HV, E-110KTL, E-125KTL-HV)




DC Connection interface (E-136KTL-HV)




Internal View 1




Internal View 2




Internal View 3




Front side of Power board



Back side of Power board



Front side of Display board



Back side of Display board




Front side of Control board



Back side of Control board



Front side of output board




Back side of output board




Front side of BUS Capacitor plate




Back side of BUS Capacitor plate




Front side of power supply board



Back side of power supply board




Front side of Communication board




Back side of Communication board




Front side of EMI input filter board



Back side of EMI input filter board




Front side of Lightning protection board



Back side of Lightning protection board




AC Connection interface



Side view




Serial Number



Software Version




2 ELECTRICAL SCHEMES



Attachment II

(Testing information)

1 TESTING CIRCUIT



Current and voltage clamps have been connected to the inverter input/output for all the tests.
 All the tests and checks have been performed in accordance with the reference standard under testing.

2 TESTING EQUIPMENT

From	No.	Equipment Name	MARK/Model No.	Equipment No.	Equipment calibration due date
BALUN	1	Digital oscilloscope	Tektronix / MS04054B	BZ-DGD-L064	2020-03-04 to 2021-03-03
	2	Current clamp	HIOKI / CT6863-05	BZ-DGD-L026-1	2020-03-04 to 2021-03-03
	3	Current clamp	HIOKI / CT6863-05	BZ-DGD-L026-2	2020-03-04 to 2021-03-03
	4	Current clamp	HIOKI / CT6863-05	BZ-DGD-L026-3	2020-03-04 to 2021-03-03
	5	Current clamp	HIOKI / CT6863-05	BZ-DGD-L026-4	2020-03-04 to 2021-03-03
	6	Power analyzer	HIOKI / PW6001-16	BZ-DGD-L025	2020-03-04 to 2021-03-03
	7	Power analyzer	DEWETRON / DEWE2-A4	BZ-DGD-L119	2020-03-04 to 2021-03-03
	8	Chamber	OK/OK-TS-6000	BZ-DGB-L028	2019-10-22 to 2020-10-21
	9	Temperature and Humidity meter	HIOKI /DT-322	BZ-DGD-L005	2020-03-07 to 2021-03-06
	10	Power analyzer	ZhiYuan / PA6000H	BZ-DGD-L059	2019-11-07 to 2020-11-06
SGS	11	True RMS Multimeter	Fluke / 187	GZE012-8	2019-12-05 to 2020-12-04

IEC 61727:2004 (50Hz/60Hz)

Items	Specifications
1) PV array simulator	
a) Voltage range	0 – 1000Vdc (0.01V step)
b) Current range	0 – 40A (0.01A step)
2) AC power source	
a) Output wiring	Three phase
b) Output capacity	30KVA
c) Output voltage	10-300Vrms
d) Output frequency	45-65Hz
e) Voltage stability	± 100ppm/°C
f) Output voltage distortion	0.05% max.
3) Digital meter	
a) Voltage range	0 – 1000Vdc, 0 – 600Vrms
b) Current range	0 – 30A
c) Frequency range (accuracy)	0.2%
d) Measurement items	Voltage (V) Current (A) Active power (W) Reactive power (Var) Volt-ampere (VA) Power factor (PF) Frequency (Hz) Electric energy (Wh)
4) Waveform recorder	
a) Sampling speed	1M/s
b) Recording device	Memory record and USB reading
c) Time accuracy	± 500ppm
5) AC load	
a) Resistive load	Maximum voltage: 300Vrms Current range: 0 – 100A Capacity: 30KW
b) Inductive load	Maximum voltage: 300Vrms Current range: 0 – 100A Capacity: 30KVA
c) Capacitive load	Maximum voltage: 300Vrms Current range: 0 – 100A Capacity: 30KVA

3 MEASUREMENT UNCERTAINTY

Magnitude	Uncertainty
Voltage measurement	$\pm 1.5 \%$
Current measurement	$\pm 2.0 \%$
Frequency measurement	$\pm 0.2 \%$
Time measurement	$\pm 0.2 \%$
Power measurement	$\pm 2.5 \%$
Phase Angle	$\pm 1^\circ$
Temperature	$\pm 3^\circ \text{C}$

Note1: Measurements uncertainties showed in this table are maximum allowable uncertainties. The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the petitioner.

Note2: Where the standard requires lower uncertainties that those in this table. Most restrictive uncertainty has been considered.

Attachment III

(GRAPHS AND SCREENSHORTS OF TEST RESULTS)

Flickers

The measurements of voltage fluctuations have been measured at 33 %, 66% and 100 % of the nominal power value of the inverter.

As it can be seen in the next screenshots, this test has two steps:

- 1.Starting operation
- 2.Stopping operation

The values took of Dmax of the two steps.







IEC 61727:2004 (50Hz/60Hz)

100% Pn (Phase A)

Flicker Mode
Flicker

Range Over

U1	U2	U3	U4	U5	U6	U7
I1	I2	I3	I4	I5	I6	I7

SCL

Line Filter

AVG

Freq Filter

CH: 1 2 3

4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 1

Volt Range 300 V/50Hz Element1 Judgement Pass

Un (U1) 230.102V Total Judgement Pass

Freq (U1) 50.002Hz (Element1,2,3)

Dmin 0.35%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:2
No. 1	0.010 Pass	0.407 Pass	0.0 Pass	0.251 Pass	
2	0.009 Pass	0.379 Pass	0.0 Pass	0.260 Pass	
Result	Pass	Pass	Pass	Pass	0.255 Pass

2020-07-25
10:20:39

⚙️

100% Pn (Phase B)

Flicker Mode
Flicker

Range Over

U1	U2	U3	U4	U5	U6	U7
I1	I2	I3	I4	I5	I6	I7

SCL

Line Filter

AVG

Freq Filter

CH: 1 2 3

4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 2

Volt Range 300 V/50Hz Element2 Judgement Pass

Un (U2) 230.218V Total Judgement Pass

Freq (U2) 50.001Hz (Element1,2,3)

Dmin 0.35%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:2
No. 1	-0.006 Pass	-0.580 Pass	0.0 Pass	0.249 Pass	
2	0.006 Pass	0.544 Pass	0.0 Pass	0.258 Pass	
Result	Pass	Pass	Pass	Pass	0.254 Pass

2020-07-25
10:20:46

⚙️

100% Pn (Phase C)

Flicker Mode
Flicker

Range Over

U1	U2	U3	U4	U5	U6	U7
I1	I2	I3	I4	I5	I6	I7

SCL

AVG

Line Filter

Freq Filter

PA_01279.tif

CH: 1 2 3
4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 3

Volt Range	300 V/50Hz	Element3	Judgement	Pass
Un (U3)	230.071V	Total	Judgement	Pass
Freq (U3)	50.002Hz	(Element1,2,3)		
Dmin	0.35%			

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:2
No. 1	0.009 Pass	0.351 Pass	0.0 Pass	0.257 Pass	
2	0.007 Pass	0.303 Pass	0.0 Pass	0.261 Pass	
Result	Pass	Pass	Pass	Pass	0.259 Pass

1% 2

2020-07-25
10:20:51

Starting operation and Stopping operation for 60Hz

33% Pn (Phase A)

Flicker Mode
Flicker

Range Over

U1	U2	U3	U4	U5	U6	U7
I1	I2	I3	I4	I5	I6	I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3

4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 1

Volt Range 300 V/60Hz Element1 Judgement Pass

Un (U1) 220.223V Total Judgement Pass

Freq (U1) 60.044Hz (Element1,2,3)

Dmin 0.35%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:2
No. 1	0.017 Pass	0.359 Pass	0.0 Pass	0.259 Pass	
2	0.013 Pass	0.365 Pass	0.0 Pass	0.265 Pass	
Result	Pass	Pass	Pass	Pass	0.262 Pass

1% 2 2020-07-26 08:45:22

Format

Measure Mode (Flicker)

Initialize

Start

Reset

PageUp

PageDown

Flicker Settings

Display Type

Graphic Settings

33% Pn (Phase B)

Flicker Mode
Flicker

Range Over

U1	U2	U3	U4	U5	U6	U7
I1	I2	I3	I4	I5	I6	I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3

4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 2

Volt Range 300 V/60Hz Element2 Judgement Pass

Un (U2) 220.223V Total Judgement Pass

Freq (U2) 60.044Hz (Element1,2,3)

Dmin 0.35%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:2
No. 1	0.009 Pass	-0.450 Pass	0.0 Pass	0.286 Pass	
2	0.013 Pass	-0.457 Pass	0.0 Pass	0.283 Pass	
Result	Pass	Pass	Pass	Pass	0.285 Pass

1% 2 2020-07-26 08:45:26

Format

Measure Mode (Flicker)

Initialize

Start

Reset

PageUp

PageDown

Flicker Settings

Display Type

Graphic Settings





IEC 61727:2004 (50Hz/60Hz)

100% Pn (Phase A)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 1

Volt Range 300 V/60Hz

Un (U1) 220.179V

Freq (U1) 60.002Hz

Dmin 0.35%

Element1 Judgement Pass

Total Judgement Pass

(Element1,2,3)

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:2
No. 1	0.005 Pass	0.408 Pass	0.0 Pass	0.285 Pass	
2	0.005 Pass	0.423 Pass	0.0 Pass	0.281 Pass	
Result	Pass	Pass	Pass	Pass	0.283 Pass

1% 2 2020-07-25 08:20:58

Item

Show

◀ Element (Element1)

◀ Limit

100% Pn (Phase B)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 2

Volt Range 300 V/60Hz

Un (U2) 220.294V

Freq (U2) 60.002Hz

Dmin 0.35%

Element2 Judgement Pass

Total Judgement Pass

(Element1,2,3)

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:2
No. 1	-0.014 Pass	-0.499 Pass	0.0 Pass	0.278 Pass	
2	0.018 Pass	0.462 Pass	0.0 Pass	0.278 Pass	
Result	Pass	Pass	Pass	Pass	0.278 Pass


1% 2 2020-07-25 08:21:05

Item

Show

◀ Element (Element2)

◀ Limit



IEC 61727:2004 (50Hz/60Hz)

As it can be seen in the next screenshots is running operation. The values took of Pst and Plt are the most unfavorable of the twelve steps.

Running operation for 50Hz

33% Pn (Phase A)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/02:00s

Element: 1

Volt Range: 600 V/50Hz

Un (Set): 230.000V

Freq (U1): 50.002Hz

Dmin: 0.50%

Element1: Total Judgement Pass

(Element1,2,3) Judgement Pass

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	-0.004	0.386	0.0	0.217	
2	0.013	0.390	0.0	0.220	
3	-0.006	-0.364	0.0	0.210	
4	-0.013	0.367	0.0	0.222	
5	0.020	0.206	0.0	0.225	
6	0.010	0.330	0.0	0.218	
7	-0.008	0.388	0.0	0.215	
8	0.010	0.223	0.0	0.216	
9	0.016	0.162	0.0	0.216	
10	0.011	0.323	0.0	0.234	
11	0.001	0.210	0.0	0.225	
12	0.019	0.355	0.0	0.228	
Result	Pass	Pass	Pass	Pass	0.221 Pass

ΣA[3P4W]

U1 600 V
I1 100 mA
Sync Src: U1
Integral: Reset

U2 600 V
I2 100 mA
Sync Src: U1
Integral: Reset

U3 600 V
I3 100 mA
Sync Src: U1
Integral: Reset

Element 4

U4 1000 V
I4 100 mA
Sync Src: U1
Integral: Reset

Element 5

U5 1000 V
I5 5 A
Sync Src: U1
Integral: Reset

Element 6

U6 1000 V
I6 5 A
Sync Src: U1
Integral: Reset

1%
2020-07-23 23:08:17

33% Pn (Phase B)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/02:00s

Element: 2

Volt Range: 600 V/50Hz

Un (Set): 230.000V

Freq (U2): 50.002Hz

Dmin: 0.50%

Element2: Total Judgement Pass

(Element1,2,3) Judgement Pass

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	-0.000	-0.503	0.0	0.224	
2	-0.012	0.540	0.0	0.227	
3	-0.004	0.523	0.0	0.232	
4	-0.004	-0.554	0.0	0.232	
5	-0.005	-0.544	0.0	0.219	
6	0.005	-0.568	0.0	0.227	
7	0.000	0.000	0.0	0.227	
8	0.016	-0.541	0.0	0.224	
9	-0.005	-0.530	0.0	0.230	
10	0.012	-0.505	0.0	0.228	
11	-0.009	-0.568	0.0	0.226	
12	-0.005	-0.538	0.0	0.233	
Result	Pass	Pass	Pass	Pass	0.227 Pass

ΣA[3P4W]

U1 600 V
I1 100 mA
Sync Src: U1
Integral: Reset

U2 600 V
I2 100 mA
Sync Src: U1
Integral: Reset

U3 600 V
I3 100 mA
Sync Src: U1
Integral: Reset

Element 4

U4 1000 V
I4 100 mA
Sync Src: U1
Integral: Reset

Element 5


U5 1000 V
I5 5 A
Sync Src: U1
Integral: Reset

Element 6

U6 1000 V
I6 5 A
Sync Src: U1
Integral: Reset

1%
2020-07-23 23:08:29

IEC 61727:2004 (50Hz/60Hz)



IEC 61727:2004 (50Hz/60Hz)

66% Pn (Phase B)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
U11 U12 U13 U14 U15 U16 U17

SCL Line Filter
AVG Freq Filter

PA_01262.tif

CH: 1 2 3
4 5 6 7

Count: 12/12 Complete
Interval: 00:00s/02:00s

Element: 2
Volt Range: 600 V/50Hz
Un (Set): 230.000V
Freq (U2): 50.001Hz
Dmin: 0.50%

Element2: (Element1,2,3)
Judgement: Pass
Total Judgement: Pass

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	0.005 Pass	0.364 Pass	0.0 Pass	0.258 Pass	
2	0.006 Pass	0.364 Pass	0.0 Pass	0.255 Pass	
3	0.007 Pass	0.369 Pass	0.0 Pass	0.252 Pass	
4	-0.007 Pass	0.403 Pass	0.0 Pass	0.251 Pass	
5	0.005 Pass	0.394 Pass	0.0 Pass	0.247 Pass	
6	-0.004 Pass	0.368 Pass	0.0 Pass	0.244 Pass	
7	-0.005 Pass	0.399 Pass	0.0 Pass	0.241 Pass	
8	-0.005 Pass	0.402 Pass	0.0 Pass	0.246 Pass	
9	0.007 Pass	0.406 Pass	0.0 Pass	0.244 Pass	
10	-0.004 Pass	0.427 Pass	0.0 Pass	0.243 Pass	
11	-0.004 Pass	0.433 Pass	0.0 Pass	0.242 Pass	
12	0.004 Pass	0.382 Pass	0.0 Pass	0.240 Pass	
Result	Pass	Pass	Pass	Pass	0.247 Pass

U1 600V U11 100mA Sync Src: U1 Integral: Reset
U2 600V U12 100mA Sync Src: U1 Integral: Reset
U3 600V U13 100mA Sync Src: U1 Integral: Reset
Element 4
U4 1000V U14 100mA Sync Src: U1 Integral: Reset
Element 5
U5 1000V U15 5A Sync Src: U1 Integral: Reset
Element 6
U6 1000V U16 5A Sync Src: U1 Integral: Reset

2020-07-23 21:05:18

66% Pn (Phase C)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
U11 U12 U13 U14 U15 U16 U17

SCL Line Filter
AVG Freq Filter

PA_01263.tif

CH: 1 2 3
4 5 6 7

Count: 12/12 Complete
Interval: 00:00s/02:00s

Element: 3
Volt Range: 600 V/50Hz
Un (Set): 230.000V
Freq (U3): 50.001Hz
Dmin: 0.50%

Element3: (Element1,2,3)
Judgement: Pass
Total Judgement: Pass

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	-0.012 Pass	0.511 Pass	0.0 Pass	0.253 Pass	
2	-0.009 Pass	-0.505 Pass	0.0 Pass	0.223 Pass	
3	-0.004 Pass	-0.508 Pass	0.0 Pass	0.219 Pass	
4	0.015 Pass	-0.520 Pass	0.0 Pass	0.222 Pass	
5	-0.013 Pass	0.590 Pass	0.0 Pass	0.226 Pass	
6	-0.008 Pass	-0.524 Pass	0.0 Pass	0.225 Pass	
7	0.003 Pass	-0.524 Pass	0.0 Pass	0.226 Pass	
8	0.000 Pass	0.000 Pass	0.0 Pass	0.232 Pass	
9	-0.026 Pass	0.565 Pass	0.0 Pass	0.221 Pass	
10	-0.012 Pass	-0.558 Pass	0.0 Pass	0.231 Pass	
11	-0.015 Pass	-0.503 Pass	0.0 Pass	0.235 Pass	
12	-0.008 Pass	0.550 Pass	0.0 Pass	0.248 Pass	
Result	Pass	Pass	Pass	Pass	0.230 Pass

U1 600V U11 100mA Sync Src: U1 Integral: Reset
U2 600V U12 100mA Sync Src: U1 Integral: Reset
U3 600V U13 100mA Sync Src: U1 Integral: Reset
Element 4
U4 1000V U14 100mA Sync Src: U1 Integral: Reset
Element 5
U5 1000V U15 5A Sync Src: U1 Integral: Reset
Element 6
U6 1000V U16 5A Sync Src: U1 Integral: Reset

2020-07-23 21:05:30

IEC 61727:2004 (50Hz/60Hz)

100% Pn (Phase A)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/10:00s

Element: 1

Volt Range: 600 V/50Hz

Un (Set): 230.000V

Freq (U1): 37.200Hz

Dmin: 0.50%

Element1: Total (Element1,2,3)

Judgement: Pass

Judgement: Pass

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
No. 1	0.148 Pass	0.330 Pass	0.0 Pass	0.323 Pass	
2	0.211 Pass	0.306 Pass	0.0 Pass	0.322 Pass	
3	0.188 Pass	0.303 Pass	0.0 Pass	0.295 Pass	
4	-0.204 Pass	-0.306 Pass	0.0 Pass	0.309 Pass	
5	0.144 Pass	0.314 Pass	0.0 Pass	0.299 Pass	
6	-0.208 Pass	-0.287 Pass	0.0 Pass	0.301 Pass	
7	0.096 Pass	0.336 Pass	0.0 Pass	0.275 Pass	
8	-0.212 Pass	-0.286 Pass	0.0 Pass	0.289 Pass	
9	0.186 Pass	0.348 Pass	0.0 Pass	0.285 Pass	
10	0.168 Pass	0.331 Pass	0.0 Pass	0.282 Pass	
11	0.118 Pass	0.346 Pass	0.0 Pass	0.278 Pass	
12	0.188 Pass	-0.327 Pass	0.0 Pass	0.283 Pass	
Result	Pass	Pass	Pass	Pass	0.296 Pass

1% x1 2020-07-23 19:02:24

Show
◀ Element (Element1)
◀ Limit

100% Pn (Phase B)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/10:00s

Element: 2

Volt Range: 600 V/50Hz

Un (Set): 230.000V

Freq (U2): 37.201Hz

Dmin: 0.50%

Element2: Total (Element1,2,3)

Judgement: Pass

Judgement: Pass

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
No. 1	-0.008 Pass	-0.534 Pass	0.0 Pass	0.357 Pass	
2	0.010 Pass	0.539 Pass	0.0 Pass	0.343 Pass	
3	-0.013 Pass	-0.601 Pass	0.0 Pass	0.344 Pass	
4	-0.010 Pass	0.560 Pass	0.0 Pass	0.323 Pass	
5	0.008 Pass	0.548 Pass	0.0 Pass	0.320 Pass	
6	-0.014 Pass	0.585 Pass	0.0 Pass	0.324 Pass	
7	-0.009 Pass	-0.570 Pass	0.0 Pass	0.297 Pass	
8	0.015 Pass	-0.562 Pass	0.0 Pass	0.291 Pass	
9	0.007 Pass	-0.611 Pass	0.0 Pass	0.307 Pass	
10	-0.023 Pass	0.570 Pass	0.0 Pass	0.314 Pass	
11	0.004 Pass	-0.567 Pass	0.0 Pass	0.306 Pass	
12	-0.011 Pass	-0.545 Pass	0.0 Pass	0.310 Pass	
Result	Pass	Pass	Pass	Pass	0.320 Pass

1% x1 2020-07-23 19:02:40

PA_01257.tif

ΣA(3P4W)
U1 600 V
I1 100 mA
Sync Src: U1
Integral: Reset

U2 600 V
I2 100 mA
Sync Src: U1
Integral: Reset

U3 600 V
I3 100 mA
Sync Src: U1
Integral: Reset

Element 4
U4 1000 V
I4 100 mA
Sync Src: U1
Integral: Reset

Element 5
U5 1000 V
I5 5 A
Sync Src: U1
Integral: Reset

Element 6
U6 1000 V
I6 5 A
Sync Src: U1
Integral: Reset

IEC 61727:2004 (50Hz/60Hz)

100% Pn (Phase C)

Flicker Mode
Flicker

Range Over

U1	U2	U3	U4	U5	U6	U7
I1	I2	I3	I4	I5	I6	I7

SCL Line Filter

AVG Freq Filter

PA_01258.tif

CH: 1 2 3
4 5 6 7

Count 12/12 Complete

Interval 00:00s/10:00s

Element 3

Volt Range 600 V/50Hz

Un (Set) 230.000V

Freq (U3) 37.200Hz

Dmin 0.50%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt			
Limit	3.30	4.00	500	1.00	0.65			
			3.30%		N:12			
No. 1	0.015	Pass	0.534	Pass	0.0	Pass	0.385	Pass
2	-0.028	Pass	-0.537	Pass	0.0	Pass	0.370	Pass
3	0.016	Pass	0.584	Pass	0.0	Pass	0.348	Pass
4	0.019	Pass	0.513	Pass	0.0	Pass	0.347	Pass
5	0.012	Pass	0.580	Pass	0.0	Pass	0.347	Pass
6	0.006	Pass	0.503	Pass	0.0	Pass	0.337	Pass
7	-0.012	Pass	-0.531	Pass	0.0	Pass	0.323	Pass
8	0.013	Pass	-0.572	Pass	0.0	Pass	0.320	Pass
9	0.006	Pass	0.516	Pass	0.0	Pass	0.317	Pass
10	0.029	Pass	-0.507	Pass	0.0	Pass	0.321	Pass
11	-0.025	Pass	-0.558	Pass	0.0	Pass	0.316	Pass
12	-0.010	Pass	0.603	Pass	0.0	Pass	0.324	Pass
Result		Pass		Pass		Pass		Pass

Element3 Judgement Pass

Total Judgement Pass

(Element1,2,3)

Σ[3P4W]

U1 600 V

I1 100 mA

Sync Src: U1

Integral: Reset

U2 600 V

I2 100 mA

Sync Src: U1

Integral: Reset

U3 600 V

I3 100 mA

Sync Src: U1

Integral: Reset

Element 4

U4 1000 V

I4 100 mA

Sync Src: U1

Integral: Reset

Element 5

U5 1000 V

I5 5 A

Sync Src: U1

Integral: Reset

Element 6

U6 1000 V


I6 5 A

Sync Src: U1

Integral: Reset

1%

2020-07-23
19:02:53



IEC 61727:2004 (50Hz/60Hz)

33% Pn (Phase C)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/10:00s

Element: 3

Volt Range: 300 V/60Hz

Un (U3): 220.005V

Freq (U3): 60.000Hz

Dmin: 0.50%

Element3 Judgement: Pass

Total Judgement: Pass

(Element1,2,3)

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	0.004 Pass	0.275 Pass	0.0 Pass	0.281 Pass	
2	0.000 Pass	0.000 Pass	0.0 Pass	0.281 Pass	
3	0.004 Pass	0.268 Pass	0.0 Pass	0.281 Pass	
4	-0.004 Pass	0.250 Pass	0.0 Pass	0.280 Pass	
5	-0.006 Pass	0.277 Pass	0.0 Pass	0.281 Pass	
6	-0.005 Pass	0.253 Pass	0.0 Pass	0.280 Pass	
7	0.005 Pass	0.268 Pass	0.0 Pass	0.280 Pass	
8	0.002 Pass	0.265 Pass	0.0 Pass	0.281 Pass	
9	-0.004 Pass	0.277 Pass	0.0 Pass	0.282 Pass	
10	0.001 Pass	0.251 Pass	0.0 Pass	0.280 Pass	
11	0.002 Pass	0.272 Pass	0.0 Pass	0.280 Pass	
12	-0.006 Pass	0.267 Pass	0.0 Pass	0.280 Pass	
Result	Pass	Pass	Pass	Pass	0.281 Pass

Element 1: U1 300V, I1 100mA, Sync Src: U1, Integral: Reset

Element 2: U2 600V, I2 100mA, Sync Src: U1, Integral: Reset

Element 3: U3 1000V, I3 10V, Sync Src: U1, Integral: Reset

Element 4: U4 1000V, I4 50mV, Sync Src: U1, Integral: Reset

Element 5: U5 1000V, I5 2V, Sync Src: U1, Integral: Reset

Element 6: U6 1000V, I6 2V, Sync Src: U1, Integral: Reset

2020-07-24 08:30:30

66% Pn (Phase A)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/10:00s

Element: 1

Volt Range: 300 V/60Hz

Un (U1): 220.095V

Freq (U1): 60.022Hz

Dmin: 0.50%

Element1 Judgement: Pass

Total Judgement: Pass

(Element1,2,3)

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	0.000 Pass	0.000 Pass	0.0 Pass	0.245 Pass	
2	0.211 Pass	0.306 Pass	0.0 Pass	0.269 Pass	
3	0.188 Pass	0.303 Pass	0.0 Pass	0.286 Pass	
4	-0.204 Pass	-0.306 Pass	0.0 Pass	0.276 Pass	
5	0.144 Pass	0.314 Pass	0.0 Pass	0.267 Pass	
6	-0.208 Pass	-0.287 Pass	0.0 Pass	0.248 Pass	
7	0.096 Pass	0.336 Pass	0.0 Pass	0.290 Pass	
8	-0.212 Pass	-0.286 Pass	0.0 Pass	0.281 Pass	
9	0.000 Pass	0.000 Pass	0.0 Pass	0.292 Pass	
10	0.168 Pass	0.331 Pass	0.0 Pass	0.211 Pass	
11	0.000 Pass	0.000 Pass	0.0 Pass	0.256 Pass	
12	0.188 Pass	-0.327 Pass	0.0 Pass	0.260 Pass	
Result	Pass	Pass	Pass	Pass	0.278 Pass

Σ(3P4W)

Element 4: U4 1000V, I4 10mA, Sync Src: U1, Integral: Reset

Element 5: U5 300V, I5 50mV, Sync Src: U1, Integral: Reset

Element 6: U6 300V, I6 1A, Sync Src: U1, Integral: Reset

2020-07-24 10:32:02

IEC 61727:2004 (50Hz/60Hz)

66% Pn (Phase B)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count 12/12 Complete

Interval 00:00s/10:00s

Element 2

Volt Range 300 V/60Hz

Un (U2) 220.095V

Freq (U2) 60.022Hz

Dmin 0.50%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	-0.169 Pass	0.287 Pass	0.0 Pass	0.253 Pass	
2	-0.137 Pass	-0.317 Pass	0.0 Pass	0.276 Pass	
3	-0.171 Pass	0.312 Pass	0.0 Pass	0.288 Pass	
4	-0.155 Pass	-0.321 Pass	0.0 Pass	0.272 Pass	
5	-0.172 Pass	-0.323 Pass	0.0 Pass	0.260 Pass	
6	0.000 Pass	0.000 Pass	0.0 Pass	0.254 Pass	
7	0.096 Pass	-0.346 Pass	0.0 Pass	0.200 Pass	
8	0.159 Pass	-0.299 Pass	0.0 Pass	0.290 Pass	
9	0.133 Pass	-0.317 Pass	0.0 Pass	0.289 Pass	
10	0.109 Pass	0.360 Pass	0.0 Pass	0.212 Pass	
11	0.197 Pass	0.309 Pass	0.0 Pass	0.253 Pass	
12	-0.147 Pass	0.301 Pass	0.0 Pass	0.260 Pass	
Result	Pass	Pass	Pass	Pass	0.280 Pass

Element 1: U1 300V, I1 10mA, Sync Src: U1, Integral: Reset

Element 2: U2 300V, I2 10mA, Sync Src: U1, Integral: Reset

Element 3: U3 300V, I3 10mA, Sync Src: U1, Integral: Reset

Element 4: U4 1000V, I4 10mA, Sync Src: U1, Integral: Reset

Element 5: U5 300V, I5 50mV, Sync Src: U1, Integral: Reset

Element 6: U6 300V, I6 1A, Sync Src: U1, Integral: Reset

2020-07-24 10:32:24

66% Pn (Phase C)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count 12/12 Complete

Interval 00:00s/10:00s

Element 3

Volt Range 300 V/60Hz

Un (U3) 220.095V

Freq (U3) 60.022Hz

Dmin 0.50%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500	1.00	0.65
			3.30%		N:12
No. 1	0.203 Pass	0.491 Pass	0.0 Pass	0.252 Pass	
2	0.000 Pass	0.000 Pass	0.0 Pass	0.256 Pass	
3	-0.127 Pass	-0.511 Pass	0.0 Pass	0.273 Pass	
4	0.000 Pass	0.000 Pass	0.0 Pass	0.273 Pass	
5	0.053 Pass	0.511 Pass	0.0 Pass	0.277 Pass	
6	0.104 Pass	0.408 Pass	0.0 Pass	0.259 Pass	
7	-0.193 Pass	-0.549 Pass	0.0 Pass	0.270 Pass	
8	0.099 Pass	-0.408 Pass	0.0 Pass	0.268 Pass	
9	0.000 Pass	0.000 Pass	0.0 Pass	0.281 Pass	
10	-0.187 Pass	-0.543 Pass	0.0 Pass	0.203 Pass	
11	0.085 Pass	-0.372 Pass	0.0 Pass	0.263 Pass	
12	-0.036 Pass	-0.573 Pass	0.0 Pass	0.265 Pass	
Result	Pass	Pass	Pass	Pass	0.272 Pass

Element 1: U1 300V, I1 10mA, Sync Src: U1, Integral: Reset

Element 2: U2 300V, I2 10mA, Sync Src: U1, Integral: Reset

Element 3: U3 300V, I3 10mA, Sync Src: U1, Integral: Reset

Element 4: U4 1000V, I4 10mA, Sync Src: U1, Integral: Reset

Element 5: U5 300V, I5 50mV, Sync Src: U1, Integral: Reset

Element 6: U6 300V, I6 1A, Sync Src: U1, Integral: Reset

2020-07-24 10:32:48

IEC 61727:2004 (50Hz/60Hz)

100% Pn (Phase A)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

PA_01254.tif

CH: 1 2 3
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/10:00s

Element: 3

Volt Range: 300 V/60Hz

Un (U3): 220.725V

Freq (U3): 60.002Hz

Dmin: 0.50%

Element3 Judgement: Pass

Total Judgement: Pass

(Element1,2,3)

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
No. 1	0.056 Pass	0.507 Pass	0.0 Pass	0.267 Pass	
2	-0.020 Pass	0.534 Pass	0.0 Pass	0.269 Pass	
3	-0.017 Pass	-0.535 Pass	0.0 Pass	0.262 Pass	
4	-0.038 Pass	-0.589 Pass	0.0 Pass	0.272 Pass	
5	0.055 Pass	-0.606 Pass	0.0 Pass	0.286 Pass	
6	0.040 Pass	0.502 Pass	0.0 Pass	0.294 Pass	
7	-0.069 Pass	0.545 Pass	0.0 Pass	0.297 Pass	
8	0.079 Pass	0.591 Pass	0.0 Pass	0.290 Pass	
9	0.075 Pass	0.543 Pass	0.0 Pass	0.288 Pass	
10	0.092 Pass	0.583 Pass	0.0 Pass	0.270 Pass	
11	0.065 Pass	0.540 Pass	0.0 Pass	0.276 Pass	
12	-0.083 Pass	0.666 Pass	0.0 Pass	0.274 Pass	
Result	Pass	Pass	Pass	Pass	0.279 Pass

1% x1 2020-07-23 16:54:13

Item: Show Element (Element3) Limit

100% Pn (Phase B)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/10:00s

Element: 1

Volt Range: 300 V/60Hz

Un (U1): 220.895V

Freq (U1): 60.002Hz

Dmin: 0.50%

Element1 Judgement: Pass

Total Judgement: Pass

(Element1,2,3)

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
No. 1	-0.061 Pass	-0.508 Pass	0.0 Pass	0.255 Pass	
2	0.063 Pass	0.503 Pass	0.0 Pass	0.262 Pass	
3	0.055 Pass	0.516 Pass	0.0 Pass	0.245 Pass	
4	0.066 Pass	0.522 Pass	0.0 Pass	0.269 Pass	
5	-0.055 Pass	-0.509 Pass	0.0 Pass	0.267 Pass	
6	-0.066 Pass	-0.566 Pass	0.0 Pass	0.304 Pass	
7	-0.052 Pass	-0.552 Pass	0.0 Pass	0.283 Pass	
8	0.062 Pass	0.563 Pass	0.0 Pass	0.274 Pass	
9	0.054 Pass	0.516 Pass	0.0 Pass	0.277 Pass	
10	0.061 Pass	0.536 Pass	0.0 Pass	0.271 Pass	
11	0.079 Pass	0.580 Pass	0.0 Pass	0.287 Pass	
12	-0.086 Pass	-0.502 Pass	0.0 Pass	0.274 Pass	
Result	Pass	Pass	Pass	Pass	0.273 Pass

1% x1 2020-07-23 16:53:35

Item: Show Element (Element1) Limit

100% Pn (Phase C)

Flicker Mode: Flicker

Range Over: U1 U2 U3 U4 U5 U6 U7 U11 U12 U13 U14 U15 U16 U17

SCL Line Filter

AVG Freq Filter

PA_01253.tif

CH: 1 2 3 4 5 6 7

Count: 12/12 Complete

Interval: 00:00s/10:00s

Element: 2

Volt Range: 300 V/60Hz

Un (U2): 220.953V

Freq (U2): 60.002Hz

Dmin: 0.50%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
No. 1	-0.025 Pass	-0.632 Pass	0.0 Pass	0.279 Pass	
2	0.021 Pass	0.740 Pass	0.0 Pass	0.262 Pass	
3	-0.042 Pass	0.672 Pass	0.0 Pass	0.277 Pass	
4	-0.053 Pass	0.634 Pass	0.0 Pass	0.254 Pass	
5	-0.069 Pass	0.783 Pass	0.0 Pass	0.281 Pass	
6	0.074 Pass	-0.644 Pass	0.0 Pass	0.284 Pass	
7	0.044 Pass	0.627 Pass	0.0 Pass	0.294 Pass	
8	-0.078 Pass	-0.777 Pass	0.0 Pass	0.280 Pass	
9	-0.090 Pass	0.642 Pass	0.0 Pass	0.281 Pass	
10	-0.094 Pass	0.777 Pass	0.0 Pass	0.277 Pass	
11	-0.075 Pass	-0.640 Pass	0.0 Pass	0.275 Pass	
12	-0.065 Pass	-0.628 Pass	0.0 Pass	0.292 Pass	
Result	Pass	Pass	Pass	Pass	0.278 Pass



Element2: Total Judgement Pass

(Element1,2,3)



Item: Show Element (Element2) Limit


2020-07-23 16:54:02

Direct current injection





Harmonics and waveform distortion







Power factor



Under-and over-voltage trip settings and reconnection test




Disconnection Time




50 % ≤ V < 85 % (setting at 155V) of 230V

Trip Value




Disconnection Time




50 %Vn ≤ V < 85 %Vn (setting at 117V) of 230V

Trip Value




Disconnection Time




V < 50%Vn (setting at 114V) of 230V

Trip Value



Disconnection Time




Under voltage Reconnection of 230V




50 %Vn ≤ V < 85 %Vn (setting at 186V) of 220V

Trip Value




Disconnection Time




50 % ≤ V < 85 % (setting at 149V) of 220V

Trip Value




Disconnection Time




50 %Vn ≤ V < 85 %Vn (setting at 111V) of 220V

Trip Value




Disconnection Time




V < 50%Vn (setting at 109V) of 220V


Trip Value



Disconnection Time




Under voltage Reconnection of 220V




110 %Vn < V < 135 %Vn(setting at 255V) of 230V

Trip value




Disconnection Time




110 %Vn < V < 135 %Vn(setting at 282V) of 230V

Trip value




Disconnection Time




110 %Vn < V < 135 %Vn(setting at 309V) of 230V

Trip value




Disconnection Time




135%Vn ≤ V(setting at 312V) of 230V


Trip value



Disconnection Time




Over voltage reconnection of 230V




110 %Vn < V < 135 %Vn(setting at 241V) of 220V

Trip value




Disconnection Time




110 %Vn < V < 135 %Vn(setting at 270V) of 220V

Trip value




Disconnection Time




110 %Vn < V < 135 %Vn(setting at 296V) of 220V

Trip value




Disconnection Time




135%Vn ≤ V(setting at 298V) of 220V


Trip value





Disconnection Time




Over voltage reconnection of 220V





Over/under frequency trip settings and reconnection test




Under frequency reconnection of 50Hz






Over frequency reconnection of 50Hz




Under frequency of 60Hz


Trip value



Disconnection time




Under frequency reconnection of 60Hz




Over frequency of 60Hz

Trip value



Disconnection time



Over frequency reconnection of 60Hz

